

---

# Faucet Documentation

*Release*

**Faucet Developers**

Dec 11, 2017



---

## Contents

---

<b>1 User Documentation</b>	<b>1</b>
1.1 Introduction to Faucet . . . . .	1
1.2 Installation . . . . .	3
1.3 Docker . . . . .	7
1.4 Configuration . . . . .	10
1.5 Configuration Recipe Book . . . . .	19
1.6 Vendor-specific Documentation . . . . .	19
1.7 External Resources . . . . .	40
<b>2 Developer Documentation</b>	<b>41</b>
2.1 Developer guide . . . . .	41
2.2 Architecture . . . . .	42
2.3 Testing . . . . .	46
2.4 Fuzzing . . . . .	49
2.5 Source Code . . . . .	49
<b>3 Quick References</b>	<b>89</b>
3.1 Frequently Asked Questions . . . . .	89
<b>4 Indices and tables</b>	<b>93</b>
<b>Python Module Index</b>	<b>95</b>



# CHAPTER 1

---

## User Documentation

---

### 1.1 Introduction to Faucet

#### 1.1.1 What is Faucet?

Faucet is a compact open source OpenFlow controller, which enables network operators to run their networks the same way they do server clusters. Faucet moves network control functions (like routing protocols, neighbor discovery, and switching algorithms) to vendor independent server-based software, versus traditional router or switch embedded firmware, where those functions are easy to manage, test, and extend with modern systems management best practices and tools. Faucet controls OpenFlow 1.3 hardware which delivers high forwarding performance.

You can read more about our approach to networking by reading our ACM Queue article [Faucet: Deploying SDN in the Enterprise](#).

#### 1.1.2 What is Gauge?

Faucet has two main OpenFlow controller components, Faucet itself, and Gauge. Faucet controls all forwarding and switch state, and exposes its internal state, e.g. learned hosts, via Prometheus (so that an open source NMS such as Grafana graph it).

Gauge also has an OpenFlow connection to the switch and monitors port and flow state (exporting it to Prometheus or InfluxDB, or even flat text log files). Gauge, however, does not ever modify the switch's state, so that switch monitoring functions can be upgraded, restarted, without impacting forwarding.

#### 1.1.3 Why Faucet?

##### Design

Faucet is designed to be very small, simple (1000s of lines of code, versus millions in other systems), and keep relatively little state. Faucet does not have any implementation-specific or vendor driver code, which considerably reduces complexity. Faucet does not need connectivity to external databases for forwarding decisions. Faucet provides

“hot/hot” high availability and scales through the provisioning of multiple Faucets with the same configuration - Faucet controllers are not inter-dependent.

### Performance and scaling

As well as being compact, Faucet offloads all forwarding to the OpenFlow switch, including flooding if emulating a traditional switch. Faucet programs the switch pre-emptively, though will receive packet headers from the switch if, for example, a host moves ports so that the switch’s OpenFlow FIB can be updated (again, if traditional switching is being emulated). In production, Faucet controllers have been observed to go many seconds without needing to process a packet from a switch. In cold start scenarios, Faucet has been observed to completely program a switch and learn connected hosts within a few seconds.

Faucet uses a multi-table packet processing pipeline as shown in [Faucet Openflow Switch Pipeline](#). Using multiple flow tables over a single table allows Faucet to implement more complicated flow-based logic while maintaining a smaller number of total flows. Using dedicated flow tables with a narrow number of match fields, or limiting a table to exact match only, such as the IPv4 or IPv6 FIB tables allows us to achieve greater scalability over the number of flow entries we can install on a datapath.

A large network with many devices would run many Faucets, which can be spread over as many (or as few) machines as required. This approach scales well because each Faucet uses relatively few server resources and Faucet controllers do not have to be centralized - they can deploy as discrete switching or routing functional units, incrementally replacing (for example) non-SDN switches or routers.

An operator might have a controller for an entire rack, or just a few switches, which also reduces control plane complexity and latency by keeping control functions simple and local.

### Testing

Faucet follows open source software engineering best practices, including unit and systems testing (python unittest based), as well static analysis (pytype, pylint, and coveralls) and fuzzing (python-afl). Faucet’s systems tests test all Faucet features, from switching algorithms to routing, on virtual topologies. However, Faucet’s systems tests can also be configured to run the same feature tests on real OpenFlow hardware. Faucet developers also host regular PlugFest events specifically to keep switch implementations broadly synchronized in capabilities and compatibility.

#### 1.1.4 Getting Help

We use maintain a number of mailing lists for communicating with users and developers:

- [faucet-announce](#)
- [faucet-dev](#)
- [faucet-users](#)

We also have the #faucetsdn IRC channel on freenode.

A few tutorial videos are available on our [YouTube channel](#).

The [faucetsdn blog](#) and [faucetsdn twitter](#) are good places to keep up with the latest news about faucet.

If you find bugs, or if have feature requests, please create an issue on our [bug tracker](#).

## 1.2 Installation

### 1.2.1 Common Installation Tasks

These tasks are required by all installation methods.

You will need to provide an initial configuration files for FAUCET and Gauge, and create directores for FAUCET and Gauge to log to.

```
mkdir -p /etc/ryu/faucet
mkdir -p /var/log/ryu/faucet
mkdir -p /var/log/ryu/gauge
$EDITOR /etc/ryu/faucet/faucet.yaml
$EDITOR /etc/ryu/faucet/gauge.yaml
```

This example `faucet.yaml` file creates an untagged VLAN between ports 1 and 2 on DP 0x1. See [Configuration](#) for more advanced configuration. See [Vendor-specific Documentation](#) for how to configure your switch.

```
vlans:
  100:
    name: "dev VLAN"
dps:
  switch-1:
    dp_id: 0x1
    interfaces:
      1:
        native_vlan: 100
      2:
        native_vlan: 100
```

This example `gauge.yaml` file instructs Gauge to poll the switch at 10s intervals and store the results in InfluxDB. See [Configuration](#) for more advanced configuration.

```
faucet_configs:
  - '/etc/ryu/faucet/faucet.yaml'
watchers:
  port_stats:
    dps: ['switch-1']
    type: 'port_stats'
    interval: 10
    db: 'influx'
  port_state:
    dps: ['switch-1']
    type: 'port_state'
    interval: 10
    db: 'influx'
dbs:
  influx:
    type: 'influx'
    influx_db: 'faucet'
    influx_host: '172.17.0.1'
    influx_port: 8086
    influx_user: 'faucet'
    influx_pwd: ''
    influx_timeout: 10
```

## 1.2.2 Encrypted Control Channel

This section outlines the steps needed to test that a switch supports self-signed certificates for TLS based Openflow connections.

### Prepare the keys and certificates

Generate key pairs for the controller.

```
/usr/bin/openssl genrsa -out /etc/ryu/ctrlr.key 2048  
/usr/bin/openssl req -new -x509 -nodes -days 3650 -subj '/C=US/ST=CA/L=Mountain View/  
O=Faucet/OU=Faucet/CN=CTRLR_1' -key /etc/ryu/ctrlr.key -out /etc/ryu/ctrlr.cert
```

Generate key pairs for the switch.

```
/usr/bin/openssl genrsa -out /etc/ryu/sw.key 2048  
/usr/bin/openssl req -new -x509 -nodes -days 3650 -subj '/C=US/ST=CA/L=Mountain View/  
O=Faucet/OU=Faucet/CN=SW_1' -key /etc/ryu/sw.key -out /etc/ryu/sw.cert
```

### Push key pairs to the switch

Copy `/etc/ryu/ctrlr.cert` `/etc/ryu/sw.key` and `/etc/ryu/sw.cert` to the switch. Configure the switch to use the keys.

For example, the command for OVS would be:

```
ovs-vsctl set-ssl /etc/ryu/sw.key /etc/ryu/sw.cert /etc/ryu/ctrlr.cert  
ovs-vsctl set-controller br0 ssl:<ctrlr_ip>:6653
```

Start Faucet with the keys (make sure the keys are readable by the user that starts the faucet process)

```
ryu-manager --ctl-privkey /etc/ryu/ctrlr.key --ctl-cert /etc/ryu/ctrlr.cert --ca-  
certs /etc/ryu/sw.cert faucet --verbose
```

### Support multiple switches

To support multiple switches, generate key pairs for each switch, and concatenate their certificates into one file and use that file as `/etc/ryu/sw.cert`.

## 1.2.3 Installation with Docker on Ubuntu with systemd

We provide official automated builds on [Docker Hub](#) so that you can easily run Faucet and it's components in a self-contained environment without installing on the main host system.

See [Docker](#) for how to install the FAUCET and Gauge images.

You can configure systemd to start the containers automatically:

```
$EDITOR /etc/systemd/system/faucet.service  
$EDITOR /etc/systemd/system/gauge.service  
systemctl daemon-reload  
systemctl enable faucet.service  
systemctl enable gauge.service
```

```
systemctl restart faucet
systemctl restart gauge
```

/etc/systemd/system/faucet.service should contain:

```
[Unit]
Description="FAUCET OpenFlow switch controller"
After=network-online.target
Wants=network-online.target
After=docker.service

[Service]
Restart=always
ExecStart=/usr/bin/docker start -a faucet
ExecStop=/usr/bin/docker stop -t 2 faucet

[Install]
WantedBy=multi-user.target
```

/etc/systemd/system/gauge.service should contain:

```
[Unit]
Description="Gauge OpenFlow switch controller"
After=network-online.target
Wants=network-online.target
After=docker.service

[Service]
Restart=always
ExecStart=/usr/bin/docker start -a gauge
ExecStop=/usr/bin/docker stop -t 2 gauge

[Install]
WantedBy=multi-user.target
```

You can check that FAUCET and Gauge are running via systemd or via docker:

```
service faucet status
service gauge status
docker ps
```

## 1.2.4 Installation with pip

You can install the latest pip package, or you can install directly from git via pip.

To install the latest pip package:

```
apt-get install python3-pip
pip3 install faucet
```

To install the latest code from git, via pip:

```
pip3 install git+https://github.com/faucetsdn/faucet.git
```

You can then start FAUCET manually:

```
ryu-manager faucet.faucet --verbose
```

Or, you can configure systemd to start the containers automatically:

```
$EDITOR /etc/systemd/system/faucet.service
$EDITOR /etc/systemd/system/gauge.service
systemctl daemon-reload
systemctl enable faucet.service
systemctl enable gauge.service
systemctl restart faucet
systemctl restart gauge
```

/etc/systemd/system/faucet.service should contain:

Listing 1.1: faucet.service

```
[Unit]
Description="Faucet OpenFlow switch controller"
After=network-online.target
Wants=network-online.target

[Service]
EnvironmentFile=/etc/default/faucet
User=faucet
Group=faucet
ExecStart=/usr/local/bin/ryu-manager --config-file=${FAUCET_RYU_CONF} --ofp-tcp-
    -listen-port=${FAUCET_LISTEN_PORT} faucet.faucet
ExecReload=/bin/kill -HUP $MAINPID
Restart=always

[Install]
WantedBy=multi-user.target
```

/etc/systemd/system/gauge.service should contain:

Listing 1.2: gauge.service

```
[Unit]
Description="Gauge OpenFlow statistics controller"
After=network-online.target
Wants=network-online.target

[Service]
EnvironmentFile=/etc/default/gauge
User=faucet
Group=faucet
ExecStart=/usr/local/bin/ryu-manager --config-file=${GAUGE_RYU_CONF} --ofp-tcp-listen-
    -port=${GAUGE_LISTEN_PORT} --wsapi-host=${WSAPI_LISTEN_HOST} faucet.gauge ryu.app.
    -ofctl_rest
Restart=always

[Install]
WantedBy=multi-user.target
```

## 1.3 Docker

### 1.3.1 Installing docker

We recommend installing Docker Community Edition (CE) according to the official [docker engine installation guide](#).

### 1.3.2 Faucet Dockerfile

This directory contains three docker files: `Dockerfile`, `Dockerfile.gauge` and `Dockerfile.tests`

### 1.3.3 Initial configuration

```
sudo mkdir -p /etc/ryu/faucet
sudo vi /etc/ryu/faucet/faucet.yaml
sudo vi /etc/ryu/faucet/gauge.yaml
```

See [Installation](#) and [Configuration](#) for configuration options.

In particular, see vendor specific docs for additional files that may be necessary in `/etc/ryu/faucet` to configure the switch pipeline.

### 1.3.4 Official builds

We provide official automated builds on Docker Hub so that you can run Faucet easily without having to build your own.

We use Docker tags to differentiate between versions of Faucet. The latest tag will always point to the latest git commit. All tagged versions of Faucet in git are also available to use, for example using the `faucet/faucet:v1_3` Docker will run the stable version 1.3 of Faucet.

To pull and run the latest git version of Faucet:

```
mkdir -p /var/log/ryu/faucet/
docker pull faucet/faucet:latest
docker run -d \
    --name faucet \
    -v /etc/ryu/faucet/:/etc/ryu/faucet/ \
    -v /var/log/ryu/faucet/:/var/log/ryu/faucet/ \
    -p 6653:6653 \
    -p 9302:9302 \
    faucet/faucet
```

Port 6653 is used for OpenFlow, port 9302 is used for Prometheus - port 9302 may be omitted if you do not need Prometheus.

To pull and run the latest git version of Gauge:

```
mkdir -p /var/log/ryu/gauge/
docker pull faucet/gauge:latest
docker run -d \
    --name gauge \
    -v /etc/ryu/faucet/:/etc/ryu/faucet/ \
    -v /var/log/ryu/gauge/:/var/log/ryu/faucet/ \
    -p 6654:6653 \
    -p 9303:9303 \
    faucet/gauge
```

Port 6654 is used for OpenFlow, port 9303 is used for Prometheus - port 9303 may be omitted if you do not need Prometheus.

### 1.3.5 Dockerfile

All that is needed to run faucet.

It can be built as following:

```
docker build -t faucet/faucet .
```

It can be run as following:

```
mkdir -p /var/log/ryu/faucet/
docker run -d \
    --name faucet \
    -v /etc/ryu/faucet/:/etc/ryu/faucet/ \
    -v /var/log/ryu/faucet/:/var/log/ryu/faucet/ \
    -p 6653:6653 \
    faucet/faucet
```

By default it listens on port 6653 for an OpenFlow switch to connect. Faucet expects to find the configuration file faucet.yaml in the config folder. If needed the -e option can be used to specify the names of files with the FAUCET\_LOG, FAUCET\_EXCEPTION\_LOG, FAUCET\_CONFIG environment variables.

### 1.3.6 Dockerfile.gauge

Runs Gauge.

It can be built as following:

```
docker build -t faucet/gauge -f Dockerfile.gauge .
```

It can be run as following:

```
mkdir -p /var/log/ryu/gauge
docker run -d \
  --name gauge \
  -v /etc/ryu/faucet:/etc/ryu/faucet/ \
  -v /var/log/ryu/gauge:/var/log/ryu/gauge/ \
  -p 6654:6653 \
  faucet/gauge
```

By default listens on port 6653. If you are running this with Faucet you will need to modify the port one of the containers listens on and configure your switches to talk to both. The faucet configuration file faucet.yaml should be placed in the config directory, this also should include to configuration for gauge.

### 1.3.7 Docker compose

This is an example docker-compose file that can be used to set up gauge to talk to prometheus and influxdb with a grafana instance for dashboards and visualisations.

It can be run with docker-compose up

The time-series databases with the default settings will write to /opt/prometheus/ /opt/influxdb/shared/data/db you can edit these locations by modifying the docker-compose.yaml file.

On OSX, some of the default shared paths are not accessible, so to overwrite the location that volumes are written to on your host, export an environment variable name FAUCET\_PREFIX and it will get prepended to the host paths. For example:

```
export FAUCET_PREFIX=/opt/faucet
```

When all the docker containers are running we will need to configure grafana to talk to prometheus and influxdb. First login to the grafana web interface on port 3000 (e.g <http://localhost:3000>) using the default credentials of admin:admin.

Then add two data sources. Use the following settings for prometheus:

```
Name: Prometheus
Type: Prometheus
Url: http://prometheus:9090
Access: proxy
```

And the following settings for influxdb:

```
Name: InfluxDB
Type: InfluxDB
Url: http://influxdb:8086
Access: proxy
With Credentials: true
Database: faucet
User: faucet
Password: faucet
```

Check the connection using test connection.

From here you can add a new dashboard and a graphs for pulling data from the data sources. See the Grafana's documentation for more on how to do this.

## 1.4 Configuration

Faucet is configured with a YAML-based configuration file, `faucet.yaml`. The following is example demonstrating a few common features:

Listing 1.3: `faucet.yaml`

```
include:
  - acls.yaml

vlans:
  office:
    vid: 100
    description: "office network"
    acl_in: office-vlan-protect
    faucet_mac: "0e:00:00:00:10:01"
    faucet_vips: ['10.0.100.254/24', '2001:100::1/64', 'fe80::c00:0ff:fe00:1001/
      ↵64']
    routes:
      - route:
          ip_dst: '192.168.0.0/24'
          ip_gw: '10.0.100.2'
  guest:
    vid: 200
    description: "guest network"
    faucet_mac: "0e:00:00:00:20:01"
    faucet_vips: ['10.0.200.254/24', '2001:200::1/64', 'fe80::c00:0ff:fe00:2001/
      ↵64']

routers:
  router-office-guest:
    vlans: [office, guest]

dps:
  sw1:
    dp_id: 0x1
    hardware: "Open vSwitch"
    proactive_learn: True
    interfaces:
      1:
        name: "h1"
        description: "host1 container"
        native_vlan: office
        acl_in: access-port-protect
      2:
        name: "h2"
        description: "host2 container"
        native_vlan: office
        acl_in: access-port-protect
      3:
        name: "g1"
        description: "guest1 container"
        native_vlan: guest
        acl_in: access-port-protect
      4:
        name: "s1"
        description: "services1 container"
        native_vlan: office
```

```

        acl_in: service-port-protect
5:
    name: "trunk"
    description: "VLAN trunk to sw2"
    tagged_vlans: [office]
    acl_in: access-port-protect
sw2:
    dp_id: 0x2
    hardware: "Allied-Telesis"
    interfaces:
        1:
            name: "pi"
            description: "Raspberry Pi"
            native_vlan: office
            acl_in: access-port-protect
        2:
            name: "laptop"
            description: "Guest Laptop"
            native_vlan: guest
            acl_in: access-port-protect
        24:
            name: "trunk"
            description: "VLAN trunk to sw1"
            tagged_vlans: [office, guest]

```

The datapath ID may be specified as an integer or hex string (beginning with 0x).

A port not explicitly defined in the YAML configuration file will be left down and will drop all packets.

Gauge is configured similarly with, gauge.yaml. The following is example demonstrating a few common features:

Listing 1.4: gauge.yaml

```

faucet_configs:
  - '/etc/ryu/faucet/faucet.yaml'
watchers:
  port_status_poller:
    type: 'port_state'
    dps: ['sw1', 'sw2']
    db: 'influx'
  port_stats_poller:
    type: 'port_stats'
    #dps: ['sw1', 'sw2']
    all_dps: True
    interval: 10
    #db: 'influx'
    db: 'prometheus'
  flow_table_poller:
    type: 'flow_table'
    interval: 60
    dps: ['sw1', 'sw2']
    #db: 'couchdb'
    db: 'influx'
dbs:
  ft_file:
    type: 'text'
    compress: True
    file: 'flow_table.yaml.gz'
  prometheus:

```

```
type: 'prometheus'
prometheus_addr: '0.0.0.0'
prometheus_port: 9303
influx:
    type: 'influx'
    influx_db: 'faucet'
    influx_host: 'influxdb'
    influx_port: 8086
    influx_user: 'faucet'
    influx_pwd: 'faucet'
    influx_timeout: 10
couchdb:
    type: gaugedb
    gdb_type: nosql
    nosql_db: couch
    db_username: couch
    db_password: 123
    db_ip: 'couchdb'
    db_port: 5984
    driver: 'couchdb'
views:
    switch_view: '_design/switches/_view/switch'
    match_view: '_design/flows/_view/match'
    tag_view: '_design/tags/_view/tags'
    switches_doc: 'switches_bak'
    flows_doc: 'flows_bak'
    db_update_counter: 2
```

### 1.4.1 Verifying configuration

You can verify that your configuration is correct with the `check_faucet_config` script:

```
check_faucet_config /etc/ryu/faucet/faucet.yaml
```

### 1.4.2 Configuration examples

For complete working examples of configuration features, see the unit tests, `tests/faucet_mininet_test.py`. For example, `FaucetUntaggedACLTest` shows how to configure an ACL to block a TCP port, `FaucetTaggedIPv4RouteTest` shows how to configure static IPv4 routing.

### 1.4.3 Applying configuration updates

You can update FAUCET's configuration by sending it a HUP signal. This will cause it to apply the minimum number of flow changes to the switch(es), to implement the change.

```
pkill -HUP -f faucet.faucet
```

### 1.4.4 Configuration in separate files

Extra DP, VLAN or ACL data can also be separated into different files and included into the main configuration file, as shown below. The `include` field is used for configuration files which are required to be loaded, and Faucet will

log an error if there was a problem while loading a file. Files listed on `include-optional` will simply be skipped and a warning will be logged instead.

Files are parsed in order, and both absolute and relative (to the configuration file) paths are allowed. DPs, VLANs or ACLs defined in subsequent files overwrite previously defined ones with the same name.

`faucet.yaml`

```
include:
  - /etc/ryu/faucet/dps.yaml
  - /etc/ryu/faucet/vlans.yaml

include-optional:
  - acl.yaml
```

`dps.yaml`

```
# Recursive include is allowed, if needed.
# Again, relative paths are relative to this configuration file.
include-optional:
  - override.yaml

dps:
  test-switch-1:
    ...
  test-switch-2:
    ...
```

## 1.4.5 Configuration options

### Top Level

Table 1.1: Faucet.yaml

Attribute	Type	Default	Description
acls	dictionary	{}	Configuration specific to acls. The keys are names of each acl, and the values are config dictionaries holding the acl's configuration (see below).
dps	dictionary	{}	Configuration specific to datapaths. The keys are names or dp_ids of each datapath, and the values are config dictionaries holding the datapath's configuration (see below).
routers	dictionary	{}	Configuration specific to routers. The keys are names of each router, and the values are config dictionaries holding the router's configuration (see below).
version	integer	2	The config version. 2 is the only supported version.
vlans	dictionary	{}	Configuration specific to vlans. The keys are names or vids of each vlan, and the values are config dictionaries holding the vlan's configuration (see below).

### DP

DP configuration is entered in the ‘dps’ configuration block. The ‘dps’ configuration contains a dictionary of configuration blocks each containing the configuration for one datapath. The keys can either be string names given to the

datapath, or the OFP datapath id.

Table 1.2: dps/&lt;dp name or id&gt;/

Attribute	Type	Default	Description
arp_neighbor_timeout	type	500	ARP and neighbour timeout in seconds
description	string	None	Description of this datapath, strictly informational
dp_id	integer	The configuration key	the OFP datapath-id of this datapath
drop_bpdu	boolean	True	If True, Faucet will drop all STP BPDUs arriving at the datapath. NB: Faucet does not handle BPDUs itself, if you disable this then you either need to configure an ACL to catch BPDUs or Faucet will forward them as though they were normal traffic.
drop_broadcast_source_address	boolean	True	If True, Faucet will drop any packet from a broadcast source address
drop_lldp	boolean	True	If True, Faucet will drop all STP BPDUs arriving at the datapath. NB: Faucet does not handle BPDUs itself, if you disable this then you either need to configure an ACL to catch BPDUs or Faucet will forward them as though they were normal traffic.
drop_spoofed_faucet_mac	bool	True	If True, Faucet will drop any packet it receives with an ethernet source address equal to a MAC address that Faucet is using.
group_table	bool	False	If True, Faucet will use the OpenFlow Group tables to flood packets. This is an experimental feature that is not fully supported by all devices and may not interoperate with all features of faucet.
hardware	string	“Open vSwitch”	The hardware model of the datapath. Defaults to “Open vSwitch”. Other options can be seen in the documentation for valve.py
ignore_learn_ins	integer	3	Ignore every approx nth packet for learning. 2 will ignore 1 out of 2 packets; 3 will ignore 1 out of 3 packets. This limits control plane activity when learning new hosts rapidly. Flooding will still be done by the dataplane even with a packet ignored for learning purposes.
interfaces	dictionary	{}	configuration block for interface specific config (see below)
interface_ranges	dictionary	{}	contains the config blocks for sets of multiple interfaces. The configuration entered here will be used as the defaults for these interfaces. This can be overwritten by configuring those interfaces directly. The format for the configuration key is a comma separated string. The elements can either be the name or number of an interface or a range of port numbers eg: “1-6,8,port9”.
learn_ban_timeout	integer	10	When a host is rapidly moving between ports Faucet will stop learning mac addresses on one of the ports for this number of seconds.
learn_jitter	integer	10	In order to reduce load on the controller Faucet will randomly vary the timeout for learnt mac addresses by up to this number of seconds.
max_host_fib_retry_count	integer	10	Limit the number of times Faucet will attempt to resolve a next-hop’s l2 address.
max_hosts_per_resolve_cycle	integer	5	Limit the number of hosts resolved per cycle.
max_resolve_backoff_time	integer	32	When resolving next hop l2 addresses, Faucet will back off exponentially until it reaches this value.
<b>name</b>	<b>Configuration</b>	string	The configuration key
stack	dictionary	{}	configuration block for stacking config, for loop protection (see below)
timeout	integer	300	timeout for MAC address learning

## Stacking (DP)

Stacking is configured in the dp configuration block and in the interface configuration block. At the dp level the following attributes can be configured within the configuration block ‘stack’:

Table 1.3: dps/<dp name or id>/stack/

Attribute	Type	Default	Description
priority	integer	0	setting any value for stack priority indicates that this datapath should be the root for the stacking topology.

## Interfaces

Configuration for each interface is entered in the ‘interfaces’ configuration block within the config for the datapath. Each interface configuration block is a dictionary keyed by the interface name.

Defaults for groups of interfaces can also be configured under the ‘interface-ranges’ attribute within the datapath configuration block. These provide default values for a number of interfaces which can be overwritten with the config block for an individual interface. These are keyed with a string containing a comma separated list of OFP port numbers, interface names or with OFP port number ranges (eg. 1-6).

Table 1.4: dps/<dp name or id>/interfaces/<interface name or OFP port number>/

Attribute	Type	Default	Description
acl_in	integer or string	None	The acl that should be applied to all packets arriving on this port. referenced by name or list index
description	string	None	Description, purely informational
enabled	boolean	True	Allow packets to be forwarded through this port.
hairpin	boolean	True	If True it allows packets arriving on this port to be output to this port. This is necessary to allow routing between two vlans on this port, or for use with a WIFI radio port.
max_hosts	integer	255	the maximum number of mac addresses that can be learnt on this port.
mirror	integer or string	None	Mirror all packets received and transmitted on this port to the port specified (by name or by port number)
name	string	The configuration key.	a name to reference this port by.
native_vlan	integer	None	The vlan associated with untagged packets arriving and leaving this interface.
number	integer	The configuration key.	The OFP port number for this port.
permanent_learn	boolean	False	When True Faucet will only learn the first MAC address on this interface. All packets with an ethernet src address not equal to that MAC address will be dropped.
stack	dictionary	None	configuration block for interface level stacking configuration
tagged_vlans	list of integers or strings	None	The vlans associated with tagged packets arriving and leaving this interfaces.
unicast_flood	boolean	True	If False unicast packets will not be flooded to this port.

## Stacking (Interfaces)

Stacking port configuration indicates how datapaths are connected when using stacking. The configuration is found under the ‘stack’ attribute of an interface configuration block. The following attributes can be configured:

Table 1.5: dps/<dp name or id>/interfaces/<interface name or port number>/stack/

Attribute	Type	Default	Description
dp	integer or string	None	the name of dp_id of the dp connected to this port
port	integer or string	None	the name or OFP port number of the interface on the remote dp connected to this interface.

## Router

Routers config is used to allow routing between vlans. Routers configuration is entered in the ‘routers’ configuration block at the top level of the faucet configuration file. Configuration for each router is an entry in the routers dictionary and is keyed by a name for the router. The following attributes can be configured:

Table 1.6: routers/<router name>/:

Attribute	Type	Default	Description
vlans	list of integers or strings	None	Enables inter-vlan routing on the given vlans

## VLAN

VLANs are configured in the ‘vlans’ configuration block at the top level of the faucet config file. The config for each vlan is an entry keyed by its vid or a name. The following attributes can be configured:

Table 1.7: vlans/&lt;vlan name or vid&gt;/:

Attribute	Type	Default	Description
acl_in	string or integer	None	The acl to be applied to all packets arriving on this vlan.
bgp_as	integer	0	The local AS number to use when speaking BGP
bgp_local_address	string (IP Address)	None	The local address to use when speaking BGP
bgp_neighbour_addresses	list of strings (IP Addresses)	None	The list of BGP neighbours
bgp_neighbour_as	integer	0	The AS Number for the BGP neighbours
bgp_port	integer	9179	Port to use for bgp sessions
description	string	None	Strictly informational
faucet_vips	list of strings (IP address prefixes)	None	The IP Address for Faucet's routing interface on this vlan
max_hosts	integer	255	The maximum number of hosts that can be learnt on this vlan.
name	string	the configuration key	A name that can be used to refer to this vlan.
proactive_arp_limit	integer	None	Do not proactively ARP for hosts once this value has been reached (unlimited by default)
proactive_nd_limit	integer	None	Don't proactively discover IPv6 hosts once this value has been reached (unlimited by default)
routes	list of routes	None	static routes configured on this vlan (see below)
unicast_flood	boolean	True	If False packets to unknown ethernet destination MAC addresses will be dropped rather than flooded.
vid	integer	the configuration key	The vid for the vlan.

## Static Routes

Static routes are given as a list. Each entry in the list contains a dictionary keyed with the keyword ‘route’ and contains a dictionary configuration block as follows:

Table 1.8: vlans/&lt;vlan name or vid&gt;/routes/[list]/route/:

Attribute	Type	Default	Description
ip_dst	string (IP subnet)	None	The destination subnet.
ip_gw	string (IP address)	None	The next hop for this route

## ACLs

ACLs are configured under the ‘acls’ configuration block. The acls block contains a dictionary of individual acls each keyed by its name.

Each acl contains a list of rules, a packet will have the first matching rule applied to it.

Each rule is a dictionary containing the single key ‘rule’ with the value the matches and actions for the rule.

The matches are key/values based on the ryu RESTful API.

Table 1.9: /acls/<acl name>/[list]/rule/actions

Attribute	Type	Default	Description
allow	boolean	False	If True allow the packet to continue through the Faucet pipeline, if False drop the packet.
meter	string	None	meter to apply to the packet
output	dict	None	used to output a packet directly. Details below.

The output action contains a dictionary with the following elements:

Table 1.10: /acls/<acl name>/[list]/rule/actions/output/

Attribute	Type	Default	Description
port	integer or string	None	The port to output the packet to.
swap_vid	integer	None	Rewrite the vlan vid of the packet when outputting
failover	dict	None	Output with a failover port (see below).

Failover is an experimental option, but can be configured as follows:

Table 1.11: /acls/<acl name>/[list]/rule/actions/output/failover/

Attribute	Type	Default	Description
group_id	integer	None	The OFP group id to use for the failover group
ports	list	None	The list of ports the packet can be output through.

## 1.5 Configuration Recipe Book

In this section we will cover some common network configurations and how you would configure these with the Faucet YAML configuration format.

### 1.5.1 Forwarding

### 1.5.2 Routing

### 1.5.3 Policy

## 1.6 Vendor-specific Documentation

### 1.6.1 Faucet on Allied Telesis products

#### Introduction

Allied Telesis has a wide portfolio of OpenFlow enabled switches that all support the Faucet pipeline. These OpenFlow enabled switches come in various port configurations of 10/18/28/52 with POE+ models as well. Here is a list of some of our most popular switches:

- AT-x930
- AT-x510
- AT-x230

### Setup

#### Switch

##### OpenFlow supported Firmware

OpenFlow has been supported since AlliedWarePlus version 5.4.6 onwards. To inquire more about compatibility of versions, you can contact our [customer support team](#).

##### OpenFlow configuration

For a **Pure OpenFlow** deployment, we recommend the following configurations on the switch. Most of these configuration steps will be shown with an example.

```
/* Create an OpenFlow native VLAN */
awplus (config)# vlan database
awplus (config-vlan)# vlan 4090

/* Set an IP address for Control Plane(CP)
 * Here we will use vlan1 for Management/Control Plane */
awplus (config)# interface vlan1
awplus (config-if)# ip address 192.168.1.1/24

/* Configure the FAUCET controller
 * Let's use TCP port 6653 for connection to Faucet */
awplus (config)# openflow controller tcp 192.168.1.10 6653

/* (OPTIONAL) Configure GAUGE controller
 * Let's use TCP port 6654 for connection to Gauge */
awplus (config)# openflow controller tcp 192.168.1.10 6654

/* User must set a dedicated native VLAN for OpenFlow ports
 * OpenFlow native VLAN MUST be created before it is set!
 * VLAN ID for this native VLAN must be different from the native VLAN for controll
e */
awplus (config)# openflow native vlan 4090

/* Enable OpenFlow on desired ports */
awplus (config)# interface port1.0.1-1.0.46
awplus (config-if)# openflow

/* Disable Spanning Tree Globally */
awplus (config)# no spanning-tree rstp enable

/* OpenFlow requires that ports under its control do not send any control traffic
 * So it is better to disable RSTP and IGMP Snooping TCN Query Solicitation.
 * Disable IGMP Snooping TCN Query Solicitation on the OpenFlow native VLAN */
awplus (config)# interface vlan4090
awplus (config-if)# no ip igmp snooping tcn query solicit
```

Once OpenFlow is up and running and connected to Faucet/Gauge controller, you should be able to verify the operation using some of our show commands.

```
/* To check contents of the DP flows */
awplus# show openflow flows

/* To check the actual rules as pushed by the controller */
awplus# show openflow rules

/* To check the OpenFlow configuration and other parameters */
awplus# show openflow status
awplus# show openflow config
awplus# show openflow coverage
```

Some other OPTIONAL configuration commands, that may be useful to modify some parameters, if needed.

```
/* Set the OpenFlow version other than default version(v1.3) */
awplus (config)# openflow version 1.0

/* Set IPv6 hardware filter size
 * User needs to configure the following command if a packet needs to be forwarded by
 * IPv6 address matching!
 * Please note that this command is supported on AT-x510 and AT-x930 only */
awplus (config)# platform hwfilter-size ipv4-full-ipv6

/* Set the datapath ID(DPID)
 * By default, we use the switch MAC address for datapath-ID.
 * To change the DPID to a hex value 0x1, use the following */
awplus (config)# openflow datapath-id 1

/* NOTE - For all software versions prior to 5.4.7, all VLAN(s) must be included in
 * the vlan database config
 * on the switch before they can be used by OpenFlow.
 * Here is an example to create DP VLANs 2-100 */
awplus (config)# vlan database
awplus (config-vlan)# vlan 2-100
```

## Faucet

Edit the faucet configuration file (/etc/ryu/faucet/faucet.yaml) to add the datapath of the switch you wish to be managed by faucet. This yaml file also contains the interfaces that need to be seen by Faucet as openflow ports. The device type (hardware) should be set to `Allied-Telesis` in the configuration file.

Listing 1.5: /etc/ryu/faucet/faucet.yaml

```
dps:
  allied-telesis:
    dp_id: 0x0000eccd6d123456
    hardware: "Allied-Telesis"
    interfaces:
      1:
        native_vlan: 100
        name: "port1.0.1"
      2:
        tagged_vlans: [2001, 2002, 2003]
        name: "port1.0.2"
        description: "windscale"
```

## References

- Allied Telesis x930
- OpenFlow Configuration Guide

### 1.6.2 Faucet on HPE-Aruba Switches

#### Introduction

All the Aruba's v3 generation of wired switches support the FAUCET pipeline. These switches include:

- 5400R
- 3810
- 2930F

The FAUCET pipeline is only supported from 16.03 release of the firmware onwards.

For any queries, please post your question on HPE's [SDN forum](#).

#### Setup

##### Switch

###### VLAN/PORT configuration

To ensure any port/vlan configuration specified in the *faucet.yaml* file works, one needs to pre-configure all vlans on the switch. Every dataplane port on the switch is made a tagged member of every vlan. This permits FAUCET to perform flow matching and packet-out on any port/vlan combination. The control-plane port (either OOBM or a front-panel port) is kept separate, so that FAUCET does not attempt to modify the control-plane port state.

- Using OOBM control-plane (3810, 5400R)

```
// Increase the maximum number of allowed VLANs on the box and save the configuration.
switch (config)# max-vlans 4094
switch (config)# write mem

// Reboot the box for the new max-vlan configuration to take affect.
switch (config)# boot system

// Configure the control-plane IP address
switch (config)# oobm ip address 20.0.0.1/24

// Create maximum number of VLANs and tag every dataplane port available to each vlan.
// Takes up to 30 minutes.
switch (config)# vlan 2-4094 tagged all
```

- Using VLAN control-plane (2930)

```
// Increase the maximum number of allowed VLANs on the box and save the configuration.
switch (config)# max-vlans 2048
switch (config)# write mem

// Reboot the box for the new max-vlan configuration to take affect.
switch (config)# boot system
```

```
// Create a control-plane vlan and add a single control-plane port (port 48)
switch (config)# vlan 2048 untagged 48

// Configure the control-plane IP address
switch (config)# vlan 2048 ip address 20.0.0.1/24

// Create maximum number of VLANs and tag every dataplane port available to each vlan,
// except for the control-plane vlan (above). Note that the command below assumes it
// is run on a 52-port switch, with port 48 as the control-plane. Takes up to 20 
  minutes.
switch (config)# vlan 2-2047 tagged 1-47,49-52
```

## OpenFlow configuration

Aruba switches reference a controller by ID, so first configure the controllers which will be used. The controller-interface matches the control-plane configuration above.

- Using OOBM control-plane (3810, 5400R)

```
// Enter OpenFlow context
switch (config)# openflow

// Configure an OpenFlow controller connection for FAUCET over tcp-port 6653
switch(openflow)# controller-id 1 ip 20.0.0.2 port 6653 controller-interface oobm

// Configure an OpenFlow controller connection for Gauge over tcp-port 6654
switch(openflow)# controller-id 2 ip 20.0.0.2 port 6654 controller-interface oobm
```

- Using VLAN control-plane (2930)

```
// Enter OpenFlow context
switch (config)# openflow

// Configure an OpenFlow controller connection for FAUCET over tcp-port 6653
switch(openflow)# controller-id 1 ip 20.0.0.2 port 6653 controller-interface vlan 2048

// Configure an OpenFlow controller connection for Gauge over tcp-port 6654
switch(openflow)# controller-id 2 ip 20.0.0.2 port 6654 controller-interface vlan 2048
```

Aruba switches support two OpenFlow instance types:

- **Aggregate** - Every VLAN on the switch apart from the controller/management VLANs are OpenFlow managed.
- **Virtualization** - A set of VLANs configured as members are OpenFlow managed.

Since FAUCET is designed for a pure OpenFlow environment, we choose the “**aggregate**” instance type.

```
// Enter the OpenFlow instance context
switch(openflow)# instance aggregate

// Associate the controllers to the instance
switch(of-inst-aggregate)# controller-id 1
switch(of-inst-aggregate)# controller-id 2

// Configure the OpenFlow version to be 1.3
switch(of-inst-aggregate)# version 1.3 only

// Configure the pipeline model type of the instance. It is a must to set it to 
  custom.
switch(of-inst-aggregate)# pipeline-model custom
```

```
// Configure the payload in the packet-ins message to be sent in its original form.
switch(of-inst-aggregate)# packet-in vlan-tagging input-form

// Ensure the switch re-attempts an OpenFlow connection at least once
// every 10 seconds when connection is dropped/inactive.
switch(of-inst-aggregate)# max-backoff-interval 10

// Allow OpenFlow to override some protocols which are otherwise excluded from
// OpenFlow processing in switch CPU.
switch(of-inst-aggregate)# override-protocol all
WARNING: Overriding the protocol can also potentially lead to control packets
          of the protocol to bypass any of the security policies like ACL(s).
Continue (y/n)? y

// Enable the instance
switch(of-inst-aggregate)# enable
switch(of-inst-aggregate)# exit

// Enable OpenFlow globally
switch(openflow)# enable
switch(openflow)# exit

// Check the OpenFlow instance configuration (includes Datapath ID associated)
switch# show openflow instance aggregate
...

// Easier way to get the Datapath ID associated with the OpenFlow instance
switch# show openflow instance aggregate | include Datapath ID
...
```

At this point, OpenFlow is enabled and running on the switch. If the FAUCET controller is running and has connected to the switch successfully, you should see the FAUCET pipeline programmed on the switch.

OpenFlow Instance Flow Table Information				
Table ID	Table Name	Flow Count	Miss Count	Goto Table
0	Port ACL	5	0	1, 2, 3, 4...
1	VLAN	10	0	2, 3, 4, 5...
2	VLAN ACL	1	0	3, 4, 5, 6...
3	Ethernet Source	2	0	4, 5, 6, 7, 8
4	IPv4 FIB	1	0	5, 6, 7, 8
5	IPv6 FIB	1	0	6, 7, 8
6	VIP	1	0	7, 8
7	Ethernet Destination	2	0	8
8	Flood	21	0	*

Table ID	Table Name	Available Free Flow Count
0	Port ACL	Ports 1-52 : 46
1	VLAN	Ports 1-52 : 91
2	VLAN ACL	Ports 1-52 : 50

```

3   Ethernet Source      Ports 1-52          : 99
4   IPv4 FIB             Ports 1-52          : 100
5   IPv6 FIB             Ports 1-52          : 100
6   VIP                  Ports 1-52          : 20
7   Ethernet Destination Ports 1-52          : 99
8   Flood                Ports 1-52          : 280

```

\* Denotes that the pipeline could end here.

## Faucet

On the FAUCET configuration file (`/etc/ryu/faucet/faucet.yaml`), add the datapath of the switch you wish to be managed by FAUCET. The device type (hardware) should be set to Aruba in the configuration file.

Listing 1.6: `/etc/ryu/faucet/faucet.yaml`

```

dps:
aruba-3810:
    dp_id: 0x00013863bbc41800
    hardware: "Aruba"
    interfaces:
        1:
            native_vlan: 100
            name: "port1"
        2:
            native_vlan: 100
            name: "port2"

```

You will also need to install pipeline configuration files (these files instruct FAUCET to configure the switch with the right OpenFlow tables - these files and FAUCET's pipeline must match).

```

sudo cp etc/ryu/faucet/ofproto_to_ryu.json /etc/ryu/faucet
sudo cp etc/ryu/faucet/aruba_pipeline.json /etc/ryu/faucet

```

## Scale

Most tables in the current FAUCET pipeline need wildcards and hence use TCAMs in hardware. There are 2000 entries available globally for the whole pipeline. Currently, it has been distributed amongst the 9 tables as follows:

Table	Maximum Entries
Port ACL	50
VLAN	300
VLAN ACL	50
ETH_SRC	500
IPv4 FIB	300
IPv6 FIB	10
VIP	10
ETH_DST	500
FLOOD	300

Based on one's deployment needs, these numbers can be updated for each table (update `max_entries` in `$(REPO_ROOT)/faucet/aruba/aruba_pipeline.json`).

---

**Note:** The summation of max entries across all 9 tables cannot cross 2000 and the minimum size of a given table has to be 2. You need to restart FAUCET for the new numbers to reflect on the switch.

---

### Limitations

- Aruba switches currently does not support all the IPv6 related functionality inside FAUCET
- Aruba switches currently does not support the OFPAT\_DEC\_NW\_TTL action (so when routing, TTL will not be decremented).

### Debug

If you encounter a failure or unexpected behavior, it may help to enable debug output on Aruba switches. Debug output displays information about what OpenFlow is doing on the switch at message-level granularity.

```
switch# debug openflow
switch# debug destination session
switch# show debug

Debug Logging

Source IP Selection: Outgoing Interface
Origin identifier: Outgoing Interface IP
Destination:
Session

Enabled debug types:
openflow
openflow packets
openflow events
openflow errors
openflow packets tx
openflow packets rx
openflow packets tx pkt_in
openflow packets rx pkt_out
openflow packets rx flow_mod
```

### References

- Aruba OpenFlow Administrator Guide (16.03)
- Aruba Switches
- FAUCET

## 1.6.3 Faucet on Lagopus

### Introduction

Lagopus is a software OpenFlow 1.3 switch, that also supports DPDK.

FAUCET is supported as of Lagopus 0.2.11 (<https://github.com/lagopus/lagopus/issues/107>).

## Setup

### Lagopus install on a supported Linux distribution

Install Lagopus according to the [quickstart guide](#). You don't need to install Ryu since we will be using FAUCET and FAUCET's installation takes care of that dependency.

These instructions are for Ubuntu 16.0.4 (without DPDK). In theory any distribution, with or without DPDK, that Lagopus supports will work with FAUCET.

### Create lagopus.dsl configuration file

In this example, Lagopus is controlling two ports, enp1s0f0 and enp1s0f1, which will be known as OpenFlow ports 1 and 2 on DPID 0x1. FAUCET and Lagopus are running on the same host (though of course, they don't need to be).

Listing 1.7: /usr/local/etc/lagopus/lagopus.dsl

```
channel channel01 create -dst-addr 127.0.0.1 -protocol tcp
controller controller01 create -channel channel01 -role equal -connection-type main
interface interface01 create -type ethernet-rawsock -device enp1s0f0
interface interface02 create -type ethernet-rawsock -device enp1s0f1
port port01 create -interface interface01
port port02 create -interface interface02
bridge bridge01 create -controller controller01 -port port01 1 -port port02 2 -dpid ↴
0x1
bridge bridge01 enable
```

### Create faucet.yaml

Listing 1.8: /etc/ryu/faucet/faucet.yaml

```
vlans:
  100:
    name: "test"
dps:
  lagopus-1:
    dp_id: 0x1
    hardware: "Lagopus"
    interfaces:
      1:
        native_vlan: 100
      2:
        native_vlan: 100
```

## Start Lagopus

Start in debug mode, in a dedicated terminal.

```
lagopus -d
```

### Run FAUCET

```
ryu-manager --config-file=/home/faucet/faucet/etc/ryu/ryu.conf /home/faucet/faucet/  
→faucet/faucet.py --verbose --ofp-listen-host=127.0.0.1
```

### Test connectivity

Host(s) on `enp1s0f0` and `enp1s0f1` in the same IP subnet, should now be able to communicate, and FAUCET's log file should indicate learning is occurring:

Listing 1.9: `/var/log/ryu/faucet.log`

```
May 11 13:04:57 faucet.valve INFO DPID 1 (0x1) Configuring DP  
May 11 13:04:57 faucet.valve INFO DPID 1 (0x1) Delete VLAN vid:100 ports:1,2  
May 11 13:04:57 faucet.valve INFO DPID 1 (0x1) VLANs changed/added: [100]  
May 11 13:04:57 faucet.valve INFO DPID 1 (0x1) Configuring VLAN vid:100 ports:1,  
→2  
May 11 13:04:57 faucet.valve INFO DPID 1 (0x1) Configuring VLAN vid:100 ports:1,  
→2  
May 11 13:04:57 faucet.valve INFO DPID 1 (0x1) Port 1 added  
May 11 13:04:57 faucet.valve INFO DPID 1 (0x1) Sending config for port 1  
May 11 13:04:57 faucet.valve INFO DPID 1 (0x1) Port 2 added  
May 11 13:04:57 faucet.valve INFO DPID 1 (0x1) Sending config for port 2  
May 11 13:04:57 faucet.valve INFO DPID 1 (0x1) Packet_in src:00:16:41:6d:87:28  
→in_port:1 vid:100  
May 11 13:04:57 faucet.valve INFO learned 1 hosts on vlan 100  
May 11 13:04:57 faucet.valve INFO DPID 1 (0x1) Packet_in src:00:16:41:32:87:e0  
→in_port:2 vid:100  
May 11 13:04:57 faucet.valve INFO learned 2 hosts on vlan 100
```

## 1.6.4 Faucet on ZodiacFX

### Introduction

ZodiacFX is a small 4 port multi table OF1.3 switch from Northbound Networks.

### Caveats

- ZodiacFX allows only one controller (so you cannot run Gauge).
- The default OF port is 6633; it is recommended to use 6653.
- It is recommended to enable ether type filtering to minimize corrupt packets.

### Applying recommended config

You can use the following expect script to program the recommended configuration:

Listing 1.10: conf-zodiac.sh

```
#!/usr/bin/expect

##
## configure ZodiacFX with recommended settings.
##

# Serial port assigned to ZodiacFX
set port /dev/ttyACM0

set timeout 5
set prompt {Zodiac_FX\#}
set configprompt {Zodiac_FX\#(config)\#}
set spawned [spawn -open [open $port w+]]

send_user "get initial prompt\n"
send "\r"
send "\r"
expect -re $prompt
send_user "found initial prompt\n"
send "config\r"
expect -re $configprompt
send_user "setting ethertype-filter\n"
send "set ethertype-filter enable\r"
expect -re $configprompt
send_user "setting of-port"
send "set of-port 6653\r"
expect -re $configprompt
send "save\r"
expect -re $configprompt
send "exit\r"
expect -re $prompt
send "restart\r"
expect -re "Restarting"
```

Example of running the script:

```
$ sudo ./conf-zodiac.sh
spawn [open ...]
get initial prompt

____ / ____ / ____ / ( ) ____ / ____ / ____ / | / |
 / / / __ \ \ / _ / / / _ \ \ / _ / / / _ \ \ / _ / | / |
 / / _ / / / / / _ / / / _ / / / _ / / / _ / / / _ / | / |
 / ____ / \ ____ / \ __, / / \ __, / / \ __ / / / / \ __ / | / |
by Northbound Networks
```

Type 'help' for a list of available commands

```
Zodiac_FX#
Zodiac_FX# found initial prompt
config
Zodiac_FX(config)# setting ethertype-filter
set ethertype-filter enable
EtherType Filtering Enabled
```

```
Zodiac_FX(config)# setting of-portset of-port 6653
OpenFlow Port set to 6653
Zodiac_FX(config)# save
Writing Configuration to EEPROM (197 bytes)
Zodiac_FX(config)# exit
Zodiac_FX# restart
Restarting the Zodiac FX, please reopen your terminal application.
```

### 1.6.5 Faucet on NoviFlow

#### Introduction

NoviFlow provide a range of switches known to work with FAUCET.

These instructions have been tested on NS1248, NS1132, NS2116, NS2128, NS2122, NS2150, NS21100 switches, using software versions NW400.1.8 to NW400.3.1, running with FAUCET v1.6.4.

When using a more recent FAUCET version, different table configurations may be required.

#### Setup

##### Configure the CPN on the switch

In this example, the server running FAUCET is 10.0.1.8; configuration for CPN interfaces is not shown.

```
set config controller controllergroup 1 controllerid 1 priority 1 ipaddr 10.0.1.8
  ↪port 6653 security none
set config switch dpid 0x1
```

##### Configure the tables

These matches are known to pass the unit tests as of FAUCET 1.6.4, but take care to adjust ACL table matches and any changes for future versions.

```
set config pipeline tablesizes 1024 1024 1024 1024 1024 1024 1024 1024 1024 1024 1024
  ↪tablewidths 80 40 40 40 40 40 40 40 40 40 40
set config table tableid 0 matchfields 0 3 4 5 6 10 14 23 29 31
set config table tableid 1 matchfields 0 3 4 5 6
set config table tableid 2 matchfields 0 5 6 10 11 12 14
set config table tableid 3 matchfields 0 3 4 5 6 10 29
set config table tableid 4 matchfields 5 6 12
set config table tableid 5 matchfields 5 6 27
set config table tableid 6 matchfields 3 5 10 23
set config table tableid 7 matchfields 0 3 6
set config table tableid 8 matchfields 0 3 6
```

#### Create faucet.yaml

Listing 1.11: /etc/ryu/faucet/faucet.yaml

```

vlans:
  100:
    name: "test"
dps:
  noviflow-1:
    dp_id: 0x1
    hardware: "NoviFlow"
    interfaces:
      1:
        native_vlan: 100
      2:
        native_vlan: 100

```

## Run FAUCET

```
ryu-manager faucet.faucet --verbose
```

## Test connectivity

Host(s) on ports 1 and 2 should now be able to communicate, and FAUCET's log file should indicate learning is occurring:

Listing 1.12: /var/log/ryu/faucet.log

```

May 14 17:06:15 faucet DEBUG DPID 1 (0x1) connected
May 14 17:06:15 faucet.valve INFO DPID 1 (0x1) Configuring DP
May 14 17:06:15 faucet.valve INFO DPID 1 (0x1) Delete VLAN vid:100 ports:1,2,3,4
May 14 17:06:15 faucet.valve INFO DPID 1 (0x1) VLANs changed/added: [100]
May 14 17:06:15 faucet.valve INFO DPID 1 (0x1) Configuring VLAN vid:100 ports:1,
→ 2,3,4
May 14 17:06:15 faucet.valve INFO DPID 1 (0x1) Configuring VLAN vid:100 ports:1,
→ 2,3,4
May 14 17:06:15 faucet.valve INFO DPID 1 (0x1) Port 1 added
May 14 17:06:15 faucet.valve INFO DPID 1 (0x1) Sending config for port 1
May 14 17:06:15 faucet.valve INFO DPID 1 (0x1) Port 2 added
May 14 17:06:15 faucet.valve INFO DPID 1 (0x1) Sending config for port 2
May 14 17:06:15 faucet.valve INFO DPID 1 (0x1) Port 3 added
May 14 17:06:15 faucet.valve INFO DPID 1 (0x1) Sending config for port 3
May 14 17:06:15 faucet.valve INFO DPID 1 (0x1) Port 4 added
May 14 17:06:15 faucet.valve INFO DPID 1 (0x1) Sending config for port 4
May 14 17:06:15 faucet.valve INFO DPID 1 (0x1) Packet_in src:62:4c:f5:bb:33:3c
→ in_port:2 vid:100
May 14 17:06:15 faucet.valve INFO learned 1 hosts on vlan 100
May 14 17:06:15 faucet.valve INFO DPID 1 (0x1) Packet_in src:62:4c:f5:bb:33:3c
→ in_port:2 vid:100
May 14 17:06:15 faucet.valve INFO DPID 1 (0x1) Packet_in src:2a:e1:65:3c:49:e4
→ in_port:3 vid:100
May 14 17:06:15 faucet.valve INFO DPID 1 (0x1) Packet_in src:2a:e1:65:3c:49:e4
→ in_port:3 vid:100
May 14 17:06:15 faucet.valve INFO learned 2 hosts on vlan 100

```

## 1.6.6 Faucet on OVS with DPDK

### Introduction

Open vSwitch is a software OpenFlow switch, that supports DPDK. It is also the reference switching platform for FAUCET.

### Setup

#### Install OVS on a supported Linux distribution

Install OVS and DPDK per the [official OVS instructions](#), including enabling DPDK at compile time and in OVS's initial configuration.

These instructions are known to work for Ubuntu 16.0.4, with OVS 2.7.0 and DPDK 16.11.1, kernel 4.4.0-77. In theory later versions of these components should work without changes. A multiport NIC was used, based on the Intel 82580 chipset.

#### Bind NIC ports to DPDK

---

**Note:** If you have a multiport NIC, you must bind all the ports on the NIC to DPDK, even if you do not use them all.

---

From the DPDK source directory, determine the relationship between the interfaces you want to use with DPDK and their PCI IDs:

```
export DPDK_DIR=`pwd`  
$DPDK_DIR/tools/dpdk-devbind.py --status
```

In this example, we want to use `enp1s0f0` and `enp1s0f1`.

```
$ ./tools/dpdk-devbind.py --status  
  
Network devices using DPDK-compatible driver  
=====  
<none>  
  
Network devices using kernel driver  
=====  
0000:01:00.0 '82580 Gigabit Network Connection' if=enp1s0f0 drv=igb unused=  
0000:01:00.1 '82580 Gigabit Network Connection' if=enp1s0f1 drv=igb unused=  
0000:01:00.2 '82580 Gigabit Network Connection' if=enp1s0f2 drv=igb unused=  
0000:01:00.3 '82580 Gigabit Network Connection' if=enp1s0f3 drv=igb unused=
```

Still from the DPDK source directory:

```
export DPDK_DIR=`pwd`  
modprobe vfio-pci  
chmod a+x /dev/vfio  
chmod 0666 /dev/vfio/*  
$DPDK_DIR/tools/dpdk-devbind.py --bind=vfio-pci 0000:01:00.0 0000:01:00.1 0000:01:00.  
 ↲ 0000:01:00.3  
$DPDK_DIR/tools/dpdk-devbind.py --status
```

## Confirm OVS has been configured to use DPDK

```
$ sudo /usr/local/share/openvswitch/scripts/ovs-ctl stop
* Exiting ovs-vswitchd (20510)
* Exiting ovsdb-server (20496)
$ sudo /usr/local/share/openvswitch/scripts/ovs-ctl start
* Starting ovsdb-server
* system ID not configured, please use --system-id
* Configuring Open vSwitch system IDs
EAL: Detected 4 lcore(s)
EAL: Probing VFIO support...
EAL: VFIO support initialized
EAL: PCI device 0000:01:00.0 on NUMA socket -1
EAL:    probe driver: 8086:150e net_e1000_igb
EAL:    using IOMMU type 1 (Type 1)
EAL: PCI device 0000:01:00.1 on NUMA socket -1
EAL:    probe driver: 8086:150e net_e1000_igb
EAL: PCI device 0000:01:00.2 on NUMA socket -1
EAL:    probe driver: 8086:150e net_e1000_igb
EAL: PCI device 0000:01:00.3 on NUMA socket -1
EAL:    probe driver: 8086:150e net_e1000_igb
EAL: PCI device 0000:02:00.0 on NUMA socket -1
EAL:    probe driver: 8086:150e net_e1000_igb
EAL: PCI device 0000:02:00.1 on NUMA socket -1
EAL:    probe driver: 8086:150e net_e1000_igb
EAL: PCI device 0000:02:00.2 on NUMA socket -1
EAL:    probe driver: 8086:150e net_e1000_igb
EAL: PCI device 0000:02:00.3 on NUMA socket -1
EAL:    probe driver: 8086:150e net_e1000_igb
Zone 0: name:<rte_eth_dev_data>, phys:0x7ffced40, len:0x30100, virt:0x7f843ffced40, ↵
↳socket_id:0, flags:0
* Starting ovs-vswitchd
* Enabling remote OVSDB managers
```

## Configure an OVS bridge with the DPDK ports

```
ovs-vsctl add-br br0 -- set bridge br0 datapath_type=netdev protocols=OpenFlow13
ovs-vsctl add-port br0 dpdk0 -- set interface enp1s0f0 type=dpdk options:dpdk-
↳devargs=0000:01:00.0
ovs-vsctl add-port br0 dpdk1 -- set interface enp1s0f1 type=dpdk options:dpdk-
↳devargs=0000:01:00.1
ovs-vsctl set-fail-mode br0 secure
ovs-vsctl set-controller br0 tcp:127.0.0.1:6653
ovs-vsctl show br0
ovs-vsctl get bridge br0 datapath_id
```

## Create faucet.yaml

---

**Note:** Change dp\_id, to the value reported above, prefaced with “0x”.

---

Listing 1.13: /etc/ryu/faucet/faucet.yaml

```

vlans:
  100:
    name: "test"
dps:
  ovsdpdk-1:
    dp_id: 0x000090e2ba7e7564
    hardware: "Open vSwitch"
    interfaces:
      1:
        native_vlan: 100
      2:
        native_vlan: 100

```

## Run FAUCET

```
ryu-manager faucet.faucet --verbose --ofp-listen-host=127.0.0.1
```

## Test connectivity

Host(s) on enp1s0f0 and enp1s0f1 in the same IP subnet, should now be able to communicate, and FAUCET's log file should indicate learning is occurring:

Listing 1.14: /var/log/ryu/faucet.log


```

May 11 14:53:32 faucet.valve INFO DPID 159303465858404 (0x90e2ba7e7564)
↳ Configuring DP
May 11 14:53:32 faucet.valve INFO DPID 159303465858404 (0x90e2ba7e7564) Delete
↳ VLAN vid:100 ports:1,2
May 11 14:53:32 faucet.valve INFO DPID 159303465858404 (0x90e2ba7e7564) VLANs
↳ changed/added: [100]
May 11 14:53:32 faucet.valve INFO DPID 159303465858404 (0x90e2ba7e7564)
↳ Configuring VLAN vid:100 ports:1,2
May 11 14:53:32 faucet.valve INFO DPID 159303465858404 (0x90e2ba7e7564)
↳ Configuring VLAN vid:100 ports:1,2
May 11 14:53:32 faucet.valve INFO DPID 159303465858404 (0x90e2ba7e7564) Port 1
↳ added
May 11 14:53:32 faucet.valve INFO DPID 159303465858404 (0x90e2ba7e7564) Sending
↳ config for port 1
May 11 14:53:32 faucet.valve INFO DPID 159303465858404 (0x90e2ba7e7564) Port 2
↳ added
May 11 14:53:32 faucet.valve INFO DPID 159303465858404 (0x90e2ba7e7564) Sending
↳ config for port 2
May 11 14:53:33 faucet.valve INFO DPID 159303465858404 (0x90e2ba7e7564) Packet_
↳ in src:00:16:41:6d:87:28 in_port:1 vid:100
May 11 14:53:33 faucet.valve INFO learned 1 hosts on vlan 100
May 11 14:53:33 faucet.valve INFO DPID 159303465858404 (0x90e2ba7e7564) Packet_
↳ in src:00:16:41:32:87:e0 in_port:2 vid:100
May 11 14:53:33 faucet.valve INFO learned 2 hosts on vlan 100

```

### 1.6.7 Faucet Testing with OVS on Hardware

#### Setup



#### Faucet configuration file

Listing 1.15: /etc/ryu/faucet/hw\_switch\_config.yaml

```
# Faucet Configuration file: /etc/ryu/faucet/hw_switch_config.yaml
#
# If hw_switch value set to True, map a hardware OpenFlow switch to ports on this_
# machine.
# Otherwise, run tests against OVS locally.
hw_switch: True
hardware: 'Open vSwitch'
dp_ports:
  1: eth0
  2: eth1
  3: eth2
  4: eth3

# Hardware switch's DPID
dpid: 0xaccd28f18b
cpn_intf: eno1
of_port: 6636
gauge_of_port: 6637
```

### Hardware

1. For Network Interface Cards (NICs), prefer Intel branded models.
2. I have also used [Hi-Speed USB to dual Ethernet](#) which works great

### Software

1. Ubuntu 16.04 Xenial
2. Open vSwitch 2.7.2+

### Commands

Commands to be executed on each side - **Faucet Test host** and **Open vSwitch**.

#### Commands on Faucet Test Host

Run these commands as root on the Ubuntu system (v16.04 used)

```
$ sudo mkdir -p /usr/local/src/
$ sudo mkdir -p /etc/ryu/faucet/
$ sudo cd /usr/local/src/
$ sudo git clone https://github.com/faucetsdn/faucet.git
$ cd faucet
$ sudo ip address show
1: lo: <LOOPBACK,UP,LOWER_UP> mtu 65536 qdisc noqueue state UNKNOWN group default
    qlen 1000
        link/loopback 00:00:00:00:00:00 brd 00:00:00:00:00:00
        inet 127.0.0.1/8 scope host lo
            valid_lft forever preferred_lft forever
        inet6 ::1/128 scope host
            valid_lft forever preferred_lft forever
2: eth0: <BROADCAST,MULTICAST,UP,LOWER_UP> mtu 1500 qdisc mq state UP group default
    qlen 1000
        link/ether b4:96:91:00:88:a4 brd ff:ff:ff:ff:ff:ff
        inet6 fe80::b696:91ff:fe00:88a4/64 scope link
            valid_lft forever preferred_lft forever
3: eth1: <BROADCAST,MULTICAST,UP,LOWER_UP> mtu 1500 qdisc mq state UP group default
    qlen 1000
        link/ether b4:96:91:00:88:a5 brd ff:ff:ff:ff:ff:ff
        inet6 fe80::b696:91ff:fe00:88a5/64 scope link
            valid_lft forever preferred_lft forever
4: eth2: <BROADCAST,MULTICAST,UP,LOWER_UP> mtu 1500 qdisc mq state UP group default
    qlen 1000
        link/ether b4:96:91:00:88:a6 brd ff:ff:ff:ff:ff:ff
        inet6 fe80::b696:91ff:fe00:88a6/64 scope link
            valid_lft forever preferred_lft forever
5: eth3: <BROADCAST,MULTICAST,UP,LOWER_UP> mtu 1500 qdisc mq state UP group default
    qlen 1000
        link/ether b4:96:91:00:88:a7 brd ff:ff:ff:ff:ff:ff
        inet6 fe80::b696:91ff:fe00:88a7/64 scope link
            valid_lft forever preferred_lft forever
6: en0: <BROADCAST,MULTICAST,UP,LOWER_UP> mtu 1500 qdisc mq state UP group default
    qlen 1000
        link/ether 00:1e:67:ff:f6:80 brd ff:ff:ff:ff:ff:ff
```

```

inet 10.10.10.7/16 brd 10.20.255.255 scope global eno1
valid_lft forever preferred_lft forever
inet6 cafe:babe::21e:67ff:feff:f680/64 scope global mngtmpaddr dynamic
valid_lft 86398sec preferred_lft 14398sec
inet6 fe80::21e:67ff:feff:f680/64 scope link
valid_lft forever preferred_lft forever

```

**Tip:** To locate the corresponding physical port, you can make the port LED blink with *Ethtool*.

## Commands on Open vSwitch

Login as `root` on the Ubuntu system and install OpenvSwitch and start `openvswitch-switch` service

```

$ sudo apt-get install openvswitch-switch
$ sudo systemctl status openvswitch-switch.service
$ sudo ovs-vsctl add-br ovs-br0
$ sudo ovs-vsctl add-port ovs-br0 enp2s0 -- set Interface enp2s0 ofport_request=1
$ sudo ovs-vsctl add-port ovs-br0 enp3s0 -- set Interface enp3s0 ofport_request=2
$ sudo ovs-vsctl add-port ovs-br0 enp5s0 -- set Interface enp5s0 ofport_request=3
$ sudo ovs-vsctl add-port ovs-br0 enp6s0 -- set Interface enp6s0 ofport_request=4
$ sudo ovs-vsctl set-fail-mode ovs-br0 secure
$ sudo ovs-vsctl set bridge ovs-br0 protocols=OpenFlow13
$ sudo ovs-vsctl set-controller ovs-br0 tcp:10.10.10.7:6636 tcp:10.10.10.7:6637
$ sudo ovs-vsctl get bridge ovs-br0 datapath_id
$ sudo ovs-vsctl show
308038ec-495d-412d-9b13-fe95bda4e176
    Bridge "ovs-br0"
        Controller "tcp:10.10.10.7:6636"
        Controller "tcp:10.10.10.7:6637"
        Port "enp3s0"
            Interface "enp3s0"
            Port "enp2s0"
                Interface "enp2s0"
            Port "enp6s0"
                Interface "enp6s0"
            Port "ovs-br0"
                Interface "ovs-br0"
                    type: internal
            Port "enp5s0"
                Interface "enp5s0"
                    type: system
        ovs_version: "2.7.0"

$ sudo ovs-vsctl -- --columns=name,ofport list Interface
    name          : "ovs-br0"
    ofport        : 65534

    name          : "enp5s0"
    ofport        : 3

    name          : "enp2s0"
    ofport        : 1

    name          : "enp6s0"

```

```
ofport : 4
name      : "enp3s0"
ofport    : 2
```

---

**Tip:** To locate the corresponding physical port, you can make the port LED blink with *Ethtool*.

---

Check port speed information to make sure that they are at least 1Gbps

```
$ sudo ovs-ofctl -O OpenFlow13 dump-ports-desc ovs-br0
OFPST_PORT_DESC reply (OF1.3) (xid=0x2):
  1(enp2s0): addr:00:0e:c4:ce:77:25
    config: 0
    state: 0
    current: 1GB-FD COPPER AUTO_NEG
    advertised: 10MB-HD 10MB-FD 100MB-HD 100MB-FD 1GB-FD COPPER AUTO_NEG AUTO_
    ↵PAUSE
    supported: 10MB-HD 10MB-FD 100MB-HD 100MB-FD 1GB-FD COPPER AUTO_NEG AUTO_
    ↵PAUSE
    speed: 1000 Mbps now, 1000 Mbps max
  2(enp3s0): addr:00:0e:c4:ce:77:26
    config: 0
    state: 0
    current: 1GB-FD COPPER AUTO_NEG
    advertised: 10MB-HD 10MB-FD 100MB-HD 100MB-FD 1GB-FD COPPER AUTO_NEG AUTO_
    ↵PAUSE
    supported: 10MB-HD 10MB-FD 100MB-HD 100MB-FD 1GB-FD COPPER AUTO_NEG AUTO_
    ↵PAUSE
    speed: 1000 Mbps now, 1000 Mbps max
  3(enp5s0): addr:00:0e:c4:ce:77:27
    config: 0
    state: 0
    current: 1GB-FD COPPER AUTO_NEG
    advertised: 10MB-HD 10MB-FD 100MB-HD 100MB-FD 1GB-FD COPPER AUTO_NEG AUTO_
    ↵PAUSE
    supported: 10MB-HD 10MB-FD 100MB-HD 100MB-FD 1GB-FD COPPER AUTO_NEG AUTO_
    ↵PAUSE
    speed: 1000 Mbps now, 1000 Mbps max
  4(enp6s0): addr:00:0a:cd:28:f1:8b
    config: 0
    state: 0
    current: 1GB-FD COPPER AUTO_NEG
    advertised: 10MB-HD COPPER AUTO_NEG AUTO_PAUSE AUTO_PAUSE_ASYM
    supported: 10MB-HD 10MB-FD 100MB-HD 100MB-FD 1GB-HD 1GB-FD COPPER AUTO_NEG
    speed: 1000 Mbps now, 1000 Mbps max
  LOCAL(ovs-br0): addr:00:0a:cd:28:f1:8b
    config: PORT_DOWN
    state: LINK_DOWN
    speed: 0 Mbps now, 0 Mbps max
```

### Running the tests

Edit the `/etc/ryu/faucet/hw_switch_config.yaml` file as shown earlier in this document setting `hw_switch=False` initially for testing.

```
$ sudo cp /usr/local/src/faucet/tests/hw_switch_config.yaml /etc/ryu/faucet/hw_switch_
˓→config.yaml
$ sudo $EDITOR /etc/ryu/faucet/hw_switch_config.yaml
$ cd /usr/local/src/faucet/
```

Install docker by following the [Installing docker](#) section and then run the hardware based tests by following the [Running the tests](#) section.

Once the above minitest version is successful with `hw_switch=False`, then edit the `/etc/ryu/faucet/hw_switch_config.yaml` file and set `hw_switch=True`.

Run tests again, verify they all pass.

## Debugging

### TCPDump

Many times, we want to know what is coming in on a port. To check on interface `enp2s0`, for example, use

```
$ sudo tcpdump -A -w enp2s0_all.pcap -i enp2s0
```

Or

```
$ sudo tcpdump -A -w enp2s0_all.pcap -i enp2s0 'dst host <controller-ip-address> and
˓→port 6653'
```

To read the pcap file, use

```
$ sudo tcpdump -r enp2s0_all.pcap
```

More detailed examples are available @ [https://www.wains.be/pub/networking/tcpdump\\_advanced\\_filters.txt](https://www.wains.be/pub/networking/tcpdump_advanced_filters.txt)

---

**Note:** On which machine should one run tcpdump?

Depends, if you want to examine the packet\_ins that are sent from switch to controller, run on the switch listening on the interface that is talking to the controller. If you are interested on what is coming in on a particular test port, then run it on the Test Host on that interface.

---

### Ethtool

To locate a physical port say `enp2s0`, make the LED blink for 5 seconds:

```
$ sudo ethtool -p enp2s0 5
```

To figure out speed on the interface. Note that if Speed on the interface is at least not 1G, then tests may not run correctly.

```
$ sudo ethtool enp2s0
$ sudo ethtool enp2s0 | grep Speed
```

## References

<https://www.garron.me/en/linux/ubuntu-network-speed-duplex-lan.html>

## 1.7 External Resources

### 1.7.1 Online Tutorials

- <http://docs.openvswitch.org/en/latest/tutorials/faucet/>
- <http://costiser.ro/2017/03/07/sdn-lesson-2-introducing-faucet-as-an-openflow-controller/>
- <https://inside-openflow.com/openflow-tracks/faucet-controller-application-technical-track/>
- <https://blog.cyberreboot.org/building-a-software-defined-network-with-raspberry-pis-and-a-zodiac-fx-switch-97184032cdc1>

### 1.7.2 Tutorial Videos

- <https://www.youtube.com/watch?v=fuqzzjmcwII>

# CHAPTER 2

---

## Developer Documentation

---

### 2.1 Developer guide

This file contains an overview of architecture, coding design/practices, testing and style.

#### 2.1.1 Before submitting a PR

- All unit tests must pass (please use the docker based tests; see [Software switch testing with docker](#)).
- It is strongly recommended to enable TravisCI testing on your repo. This enables the maintainers to quickly verify that your changes pass all tests in a pristine environment.
- You must add a test if FAUCET's functionality changes (ie. a new feature, or correcting a bug).
- pylint must show no new errors or warnings.
- Code must conform to the style guide (see below).

#### 2.1.2 Code style

Please use the coding style documented at <http://google.github.io/styleguide/pyguide.html>. Existing code not using this style will be incrementally migrated to comply with it. New code should comply.

#### 2.1.3 Makefile

Makefile is provided at the top level of the directory. Output of make is normally stored in `dist` directory. The following are the targets that can be used:

- **uml**: Uses `pyreverse` to provide code class diagrams.
- **dot**: Uses `dot` to provide hierarchical representation of `faucet.yaml` based on `docs/images/faucet-yaml.dot` file

- **codefmt**: Provides command line usage to “Code Style” the Python file
- **codeerrors**: Uses pylint on all Python files to generate a code error report and is placed in `dist` directory.
- **stats**: Provides a list of all commits since the last release tag.
- **release**: Used for releasing FAUCET to the next version, Requires `version` and `next_version` variables.

To *directly install* faucet from the cloned git repo, you could use `sudo python setup.py install` command from the root of the directory.

To *build pip installable package*, you could use `python setup.py sdist` command from the root of the directory.

To *remove* any temporarily created directories and files, you could use `rm -rf dist *egg-info` command.

### 2.1.4 Key architectural concepts/assumptions:

FAUCET’s architecture depends on key assumptions, which must be kept in mind at all times.

- FAUCET is the only controller for the switch, that can add or remove flows.
- All supported dataplanes must implement OpenFlow functionally (hardware, software or both) identically. No TTP or switch specific drivers.

In addition:

- FAUCET provisions default deny flows (all traffic not explicitly programmed is dropped).
- Use of packet in is minimized.

FAUCET depends upon these assumptions to guarantee that the switch is always in a known and consistent state, which in turn is required to support high availability (FAUCET provides high availability, through multiple FAUCET controllers using the same version of configuration - any FAUCET can give the switch a consistent response - no state sharing between controllers is required). The FAUCET user can program customized flows to be added to the switch using FAUCET ACLs (see below).

FAUCET also programs the dataplane to do flooding (where configured). This minimizes the use of packet in. This is necessary to reduce competition between essential control plane messages (adding and removing flows), and traffic from the dataplane on the limited bandwidth OpenFlow control channel. Unconstrained packet in messages impact the switch CPU, may overwhelm the OpenFlow control channel, and will expose the FAUCET controller to unvalidated dataplane packets, all of which are security and reliability concerns. In future versions, packet in will be eliminated altogether. The FAUCET user is expected to use policy based forwarding (eg ACLs that redirect traffic of interest to high performance dataplane ports for NFV offload), not packet in.

FAUCET requires all supported dataplanes to implement OpenFlow (specifically, a subset of OpenFlow 1.3) in a functionally identical way. This means that there is no switch-specific driver layer - the exact same messages are sent, whether the switch is OVS or hardware. While this does prevent some earlier generation OpenFlow switches from being supported, commercially available current hardware does not have as many restrictions, and eliminating the need for a switch-specific (or TTP) layer greatly reduces implementation complexity and increases controller programmer productivity.

## 2.2 Architecture

### 2.2.1 Faucet Design and Architecture


Faucet enables practical SDN for the masses (see <http://queue.acm.org/detail.cfm?id=3015763>).

- Drop in/replacement for non-SDN L2/L3 IPv4/IPv6 switch/router (easy migration)

- Packet forwarding/flooding/multicasting done entirely by switch hardware (controller only notified on topology change)
- BGP and static routing (other routing protocols provided by NFV)
- Multi vendor/platform support using OpenFlow 1.3 multi table
- Multi switch, vendor neutral “stacking” (Faucet distributed switching, loop free topology without spanning tree)
- ACLs, as well as allow/drop, allow packets to be copied/rewritten for external NFV applications
- Monitored with Prometheus
- Small code base with high code test coverage and automated testing both hardware and software

See unit and integration tests for working configuration examples.

## 2.2.2 Faucet Openflow Switch Pipeline



**Table 0: PORT\_ACL**

- Apply user supplied ACLs to a port and send to next table

**Table 1: VLAN**

- Match fields: `eth_dst`, `eth_type`, `in_port`, `vlan_vid`
- **Operations:**
  - Drop unwanted L2 protocol traffic (and spoofing of Faucet's virtual MAC)
  - **For tagged ports**
    - \* Match `VLAN_VID` and send to next table
  - **For untagged ports**
    - \* Push VLAN frame onto packet with `VLAN_VID` representing ports native VLAN and send to next table
  - Unknown traffic is dropped

**Table 2: VLAN\_ACL**

- Apply user supplied ACLs to a VLAN and send to next table

**Table 3: ETH\_SRC**

- Match fields: `eth_dst`, `eth_src`, `eth_type`, `in_port`, `vlan_vid`
- **Operations:**
  - For IPv4/IPv6 traffic where Faucet is the next hop, send to IPV4\_FIB or IPV6\_FIB (route)
  - For known source MAC, send to ETH\_DST (switch)
  - For unknown source MACs, copy header to controller via packet in (for learning) and send to FLOOD

**Table 4: IPV4\_FIB**

- Match fields: `eth_type`, `ipv4_dst`, `vlan_vid`
- **Operations:**
  - Route IPv4 traffic to a next-hop for each route we have learned
  - Set `eth_src` to Faucet's magic MAC address
  - Set `eth_dst` to the resolved MAC address for the next-hop
  - Decrement TTL
  - Send to ETH\_DST table
  - Unknown traffic is dropped

**Table 5: IPV6\_FIB**

- Match fields: eth\_type, ipv6\_dst, vlan\_vid
- **Operations:**
  - Route IPv4 traffic to a next-hop for each route we have learned
  - Set eth\_src to Faucet's magic MAC address
  - Set eth\_dst to the resolved MAC address for the next-hop
  - Decrement TTL
  - Send to ETH\_DST table
  - Unknown traffic is dropped

**Table 6: VIP**

- Match fields: arp\_tpa, eth\_dst, eth\_type, icmpv6\_type, ip\_proto
- **Operations:**
  - Send traffic destined for FAUCET VIPs including IPv4 ARP and IPv6 ND to the controller.
  - IPv6 ND traffic may be flooded also (sent to FLOOD)


**Table 7: ETH\_DST**

- Match fields: eth\_dst, in\_port, vlan\_vid
- **Operations:**
  - For destination MAC addresses we have learned output packet towards that host (popping VLAN frame if we are outputting on an untagged port)
  - Unknown traffic is sent to FLOOD table

**Table 8: FLOOD**

- Match fields: eth\_dst, in\_port, vlan\_vid
- **Operations:**
  - Flood broadcast within VLAN
  - Flood multicast within VLAN
  - Unknown traffic is flooded within VLAN

### 2.2.3 Faucet Architecture



## 2.3 Testing

### 2.3.1 Installing docker

First, get yourself setup with docker based on our [Installing docker](#) documentation.


### 2.3.2 Software switch testing with docker

Then you can build and run the mininet tests from the docker entry-point:

```
sudo docker build -t faucet/tests -f Dockerfile.tests .
sudo apparmor_parser -R /etc/apparmor.d/usr.sbin.tcpdump
sudo modprobe openvswitch
sudo docker run --sysctl net.ipv6.conf.all.disable_ipv6=0 --privileged -ti faucet/
→tests
```

The apparmor command is currently required on Ubuntu hosts to allow the use of tcpdump inside the container.

### 2.3.3 Hardware switch testing with docker



### Requirements

Your test host, requires at least 5 interfaces. 4 interfaces to connect to the dataplane, and one for the CPN for OpenFlow. You will need to assign an IP address to the CPN interface on the host, and configure the switch with a CPN IP address and establish that they can reach each other (eg via ping).

You will need to configure the switch with two OpenFlow controllers, both with the host's CPN IP address, but with different ports (defaults are given below for *of\_port* and *gauge\_of\_port*).

It is assumed that you execute all following commands from your FAUCET source code directory (eg one you have git cloned).

### Test configuration

Create a directory for the test configuration:

```
mkdir -p /etc/ryu/faucet  
$EDITOR /etc/ryu/faucet/hw_switch_config.yaml
```

hw\_switch\_config.yaml should contain the correct configuration for your switch:

```
hw_switch: True  
hardware: 'Open vSwitch'  
# Map ports on the hardware switch, to physical ports on this machine.  
# If using a switch with less than 4 dataplane ports available, run  
# FaucetZodiac tests only. A 4th port must still be defined here and  
# must exist, but will not be used.  
dp_ports:  
    1: enp1s0f0  
    2: enp1s0f1  
    3: enp1s0f2  
    4: enp1s0f3  
# Hardware switch's DPID  
dpid: 0xecccd6d9936ed  
# Port on this machine that connects to hardware switch's CPN port.  
# Hardware switch must use IP address of this port as controller IP.  
cpn_intf: enp5s0  
# There must be two controllers configured on the hardware switch,  
# with same IP (see cpn_intf), but different ports - one for FAUCET,  
# one for Gauge.  
of_port: 6636  
gauge_of_port: 6637  
# If you wish to test OF over TLS to the hardware switch,  
# set the following parameters per Ryu documentation.  
# https://github.com/osrg/ryu/blob/master/doc/source/tls.rst  
# ctl_privkey: ctl-privkey.pem  
# ctl_cert: ctl-cert.pem  
# ca_certs: /usr/local/var/lib/openvswitch/pki/switchca/cacert.pem
```

### Running the tests

```
docker build -t faucet/tests -f Dockerfile.tests .  
apparmor_parser -R /etc/apparmor.d/usr.sbin.tcpdump  
modprobe openvswitch  
sudo docker run --privileged --net=host \  
    -v /etc/ryu/faucet:/etc/ryu/faucet \  
    -v /tmp:/tmp \  
    -ti faucet/tests
```

### Running a single test

```
sudo docker run --privileged --net=host \
-e FAUCET_TESTS="FaucetUntaggedTest" \
-v /etc/ryu/faucet:/etc/ryu/faucet \
-v /tmp:/tmp \
-ti faucet/tests
```

## Checking test results

If a test fails, you can look in /tmp - there will be subdirectories created for each test, which will contain all the logs and debug information (including tcpdumps).

## 2.4 Fuzzing

### 2.4.1 Fuzzing faucet with docker

First, get yourself setup with docker based on our [Docker](#) documentation.

Then you can build and run the afl-fuzz tests:

```
docker build -t faucet/fuzzer -f Dockerfile.fuzz .

docker run -d \
-u $(id -u $USER) \
--name fuzzer \
-v /var/log/afl/:/var/log/afl/ \
faucet/fuzzer
```

AFL then will run indefinitely. You can find the output in /var/log/afl/.

## 2.5 Source Code

### 2.5.1 faucet

#### faucet package

##### Submodules

##### faucet.acl module

Configuration for ACLs.

**class** `faucet.acl.ACL(_id, dp_id, conf)`  
 Bases: `faucet.conf.Config`

Contains the state for an ACL, including the configuration.

##### ACL Config

ACLs are configured under the ‘acls’ configuration block. The acls block contains a dictionary of individual acls each keyed by its name.

Each acl contains a list of rules, a packet will have the first matching rule applied to it.

Each rule is a dictionary containing the single key ‘rule’ with the value the matches and actions for the rule.

The matches are key/values based on the ryu RESTful API. The key ‘actions’ contains a dictionary with keys/values as follows:

- allow (bool): if True allow the packet to continue through the Faucet pipeline, if False drop the packet.
- meter (str): meter to apply to the packet
- output (dict): used to output a packet directly. details below.

The output action contains a dictionary with the following elements:

- port (int or string): the port to output the packet to
- swap\_vid (int): rewrite the vlan vid of the packet when outputting
- failover (dict): Output with a failover port. The following elements can be configured.
- group\_id (int): the ofp group id to use for the group
- ports (list): a list of the ports the packet can be output through

```
defaults = {'rules': None, 'exact_match': False}
defaults_types = {'rules': <class 'list'>, 'exact_match': <class 'bool'>}
exact_match = None
mirror_destinations = set()
rules = None
to_conf()
```

### faucet.check\_faucet\_config module

Standalone script to check FAUCET configuration, return 0 if provided config OK.

```
faucet.check_faucet_config.check_config(conf_files)
faucet.check_faucet_config.main()
```

### faucet.conf module

Base configuration implementation.

```
class faucet.conf.Conf(_id, dp_id, conf=None)
Bases: object
Base class for FAUCET configuration.

check_config()
As far as possible, check config at instantiation time for errors, typically via assert.

conf_hash(dyn=False, subconf=True, ignore_keys=None)

defaults = {}
defaults_types = {}
dyn_finalized = False
dyn_hash = None
```

---

```

finalize()
    Configuration parsing marked complete.

ignore_subconf (other, ignore_keys=None)
    Return True if this config same as other, ignoring sub config.

merge_dyn (other_conf)
    Merge dynamic state from other conf object.

set_defaults()
    Set default values and run any basic sanity checks.

to_conf()
    Return configuration as a dict.

update (conf)
    Parse supplied YAML config and sanity check.

exception faucet.conf.InvalidConfigError
Bases: Exception

This error is thrown when the config file is not valid.

```

## **faucet.config\_parser module**

Implement configuration file parsing.

```

faucet.config_parser.dp_parser (config_file, logname)
faucet.config_parser.get_config_for_api (valves)
    Return config as dict for all DPs.

faucet.config_parser.watcher_parser (config_file, logname, prom_client)
    Return Watcher instances from config.

```

## **faucet.config\_parser\_util module**

Utility functions supporting FAUCET/Gauge config parsing.

```

faucet.config_parser_util.config_changed (top_config_file,      new_top_config_file,      con-
fig_hashes)
    Return True if configuration has changed.

```

### **Parameters**

- **top\_config\_file** (*str*) – name of FAUCET config file
- **new\_top\_config\_file** (*str*) – name, possibly new, of FAUCET config file.
- **config\_hashes** (*dict*) – map of config file/includes and hashes of contents.

**Returns** True if the file, or any file it includes, has changed.

**Return type** bool

```

faucet.config_parser_util.config_file_hash (config_file_name)
    Return hash of YAML config file contents.

faucet.config_parser_util.dp_config_path (config_file, parent_file=None)
    Return full path to config file.

faucet.config_parser_util.dp_include (config_hashes, config_file, logname, top_confs)

```

```
faucet.config_parser_util.get_logger(logname)
    Return logger instance for config parsing.

faucet.config_parser_util.no_duplicates_constructor(loader, node, deep=False)
    Check for duplicate YAML keys.

faucet.config_parser_util.read_config(config_file, logname)
    Return a parsed YAML config file or None.
```

### faucet.dp module

Configuration for a datapath.

```
class faucet.dp.DP(_id, dp_id, conf)
    Bases: faucet.conf.Conf
```

Stores state related to a datapath controlled by Faucet, including configuration.

```
acls = None
```

```
add_acl(acl_ident, acl)
```

Add an ACL to this DP.

```
add_port(port)
```

Add a port to this DP.

```
add_router(router_ident, router)
```

Add a router to this DP.

```
add_vlan(vlan)
```

Add a VLAN to this datapath.

```
advertise_interval = None
```

```
all_valve_tables()
```

Return list of all Valve tables.

```
arp_neighbor_timeout = None
```

```
check_config()
```

```
configured = False
```

```
cookie = None
```

```
defaults = {'drop_lldp': True, 'group_table_routing': False, 'max_host_fib_retry_cou
```

```
defaults_types = {'drop_lldp': <class 'bool'>, 'group_table_routing': <class 'bool'>
```

```
dp_id = None
```

```
drop_bpdu = None
```

```
drop_broadcast_source_address = None
```

```
drop_lldp = None
```

```
drop_spoofed_faucet_mac = None
```

```
finalize_config(dps)
```

Perform consistency checks after initial config parsing.

```
get_config_changes(logger, new_dp)
```

Detect any config changes.

**Parameters**

- **logger** ([ValveLogger](#)) – logger instance
- **new\_dp** ([DP](#)) – new dataplane configuration.

**Returns**

changes tuple containing:

deleted\_ports (set): deleted port numbers. changed\_ports (set): changed/added port numbers. changed\_acl\_ports (set): changed ACL only port numbers. deleted\_vlans (set): deleted VLAN IDs. changed\_vlans (set): changed/added VLAN IDs. all\_ports\_changed (bool): True if all ports changed.

**Return type** (tuple)

**get\_config\_dict()**

Return DP config as a dict for API call.

**get\_native\_vlan(port\_num)**

Return native VLAN for a port by number, or None.

**get\_tables()**

Return tables as dict for API call.

**group\_table = False**

**group\_table\_routing = False**

**groups = None**

**high\_priority = None**

**ignore\_learn\_ins = None**

**in\_port\_tables()**

Return list of tables that specify in\_port as a match.

**interface\_ranges = None**

**interfaces = None**

**learn\_ban\_timeout = None**

**learn\_jitter = None**

**low\_priority = None**

**match\_tables(match\_type)**

Return list of tables with matches of a specific match type.

**max\_host\_fib\_retry\_count = None**

**max\_hosts\_per\_resolve\_cycle = None**

**max\_resolve\_backoff\_time = None**

**meters = {}**

**name = None**

**packetin\_pps = None**

**peer\_stack\_up\_ports(peer\_dp)**

Return list of stack ports that are up towards a peer.

**pipeline\_config\_dir = None**

```
ports = None
priority_offset = None
proactive_learn = None
resolve_stack_topology(dps)
    Resolve inter-DP config for stacking.

routers = None
running = False
set_defaults()
shortest_path(dest_dp)
    Return shortest path to a DP, as a list of DPs.
shortest_path_port(dest_dp)
    Return first port on our DP, that is the shortest path towards dest DP.
shortest_path_to_root()
    Return shortest path to root DP, as list of DPs.

stack = None
stack_ports = None
tables = {}
tables_by_id = {}
timeout = None
to_conf()
    Return DP config as dict.
use_idle_timeout = None
vlan_match_tables()
    Return list of tables that specify vlan_vid as a match.
vlans = None
wildcard_table = <faucet.valve_table.ValveTable object>
```

## faucet.faucet module

RyuApp shim between Ryu and Valve.

```
class faucet.faucet.EventFaucetAdvertise
    Bases: ryu.controller.event.EventBase
    Event used to trigger periodic network advertisements (eg IPv6 RAs).

class faucet.faucet.EventFaucetExperimentalAPIRegistered
    Bases: ryu.controller.event.EventBase
    Event used to notify that the API is registered with Faucet.

class faucet.faucet.EventFaucetMetricUpdate
    Bases: ryu.controller.event.EventBase
    Event used to trigger update of metrics.
```

```

class faucet.faucet.EventFaucetReconfigure
    Bases: ryu.controller.event.EventBase
    Event used to trigger FAUCET reconfiguration.

class faucet.faucet.EventFaucetResolveGateways
    Bases: ryu.controller.event.EventBase
    Event used to trigger gateway re/resolution.

class faucet.faucet.EventFaucetStateExpire
    Bases: ryu.controller.event.EventBase
    Event used to trigger expiration of state in controller.

class faucet.faucet.Faucet(*args, **kwargs)
    Bases: ryu.base.app_manager.RyuApp
    A RyuApp that implements an L2/L3 learning VLAN switch.

    Valve provides the switch implementation; this is a shim for the Ryu event handling framework to interface with Valve.

OFP_VERSIONS = [4]

advertise(_)
    Handle a request to advertise services.

connect_or_disconnect_handler(ryu_event)
    Handle connection or disconnection of a datapath.

        Parameters ryu_event (ryu.controller.dpset.EventDP) – trigger.

desc_stats_reply_handler(ryu_event)
    Handle OFPDescStatsReply from datapath.

        Parameters ryu_event (ryu.controller.ofp_event.EventOFPDescStatsReply) – trigger.

error_handler(ryu_event)
    Handle an OFPError from a datapath.

        Parameters ryu_event (ryu.controller.ofp_event.EventOFPErrorMsg) – trigger.

exc_logname = 'faucet.exception'

features_handler(ryu_event)
    Handle receiving a switch features message from a datapath.

        Parameters ryu_event (ryu.controller.ofp_event.EventOFPStateChange) – trigger.

flowremoved_handler(ryu_event)
    Handle a flow removed event.

        Parameters ryu_event (ryu.controller.ofp_event.EventOFPFlowRemoved) – trigger.

get_config()
    FAUCET experimental API: return config for all Valves.

get_tables(dp_id)
    FAUCET experimental API: return config tables for one Valve.

logname = 'faucet'

```

```
metric_update(_)
    Handle a request to update metrics in the controller.

packet_in_handler(ryu_event)
    Handle a packet in event from the dataplane.

    Parameters ryu_event (ryu.controller.event.EventReplyBase) – packet in
        message.

port_status_handler(ryu_event)
    Handle a port status change event.

    Parameters ryu_event (ryu.controller.ofp_event.EventOFPPortStatus) –
        trigger.

reconnect_handler(ryu_event)
    Handle reconnection of a datapath.

    Parameters ryu_event (ryu.controller.dpset.EventDPReconnected) – trig-
        ger.

reload_config(_)
    Handle a request to reload configuration.

resolve_gateways(_)
    Handle a request to re/resolve gateways.

start()
state_expire(_)
    Handle a request expire host state in the controller.
```

### faucet.faucet\_bgp module

BGP implementation for FAUCET.

```
class faucet.faucet_bgp.FaucetBgp(logger, send_flow_msgs)
    Bases: object

    reset(valves, metrics)
        Set up a BGP speaker for every VLAN that requires it.

    update_metrics()
        Update BGP metrics.
```

### faucet.faucet\_experimental\_api module

Implement experimental API.

```
class faucet.faucet_experimental_api.FaucetExperimentalAPI(*args, **kwargs)
    Bases: object

    An experimental API for communicating with Faucet.

    Contains methods for interacting with a running Faucet controller from within a RyuApp. This app should be
    run together with Faucet in the same ryu-manager process.

    add_port_acl(port, acl)
        Add an ACL to a port.
```

---

```

add_vlan_acl (vlan, acl)
    Add an ACL to a VLAN.

delete_port_acl (port, acl)
    Delete an ACL from a port.

delete_vlan_acl (vlan, acl)
    Delete an ACL from a VLAN.

get_config()
    Get the current running config of Faucet as a python dictionary.

get_tables (dp_id)
    Get current FAUCET tables as a dict of table name: table no.

is_registered()
    Return True if registered and ready to serve API requests.

push_config (config)
    Push supplied config to FAUCET.

reload_config()
    Reload config from config file in FAUCET_CONFIG env variable.

```

## **faucet.faucet\_experimental\_event module**

Experimental FAUCET event notification.

```

class faucet.faucet_experimental_event.FaucetExperimentalEventNotifier (socket_path,
                                                               met-
                                                               rics,
                                                               log-
                                                               ger)
Bases: object

Event notification, via Unix domain socket.

notify (dp_id, dp_name, event_dict)
    Notify of an event.

start()
    Start socket server.

```

## **faucet.faucet\_metrics module**

Implement Prometheus statistics.

```

class faucet.faucet_metrics.FaucetMetrics
Bases: faucet.prom_client.PromClient

Container class for objects that can be exported to Prometheus.

reset_dpid (dp_labels)
    Set all DPID-only counter/gauges to 0.

```

## **faucet.fctl module**

Report state based on FAUCET/Gauge/Prometheus variables.

```
faucet.fctl.main()  
faucet.fctl.report_label_match_metrics(report_metrics, metrics, nonzero_only=False, de-  
lim='\\t', label_matches=None)  
    Text report on a list of Prometheus metrics.  
faucet.fctl.scrape_prometheus(endpoints, retries=3)  
    Scrape a list of Prometheus/FAUCET/Gauge endpoints and aggregate results.  
faucet.fctl.usage()
```

### faucet.gauge module

RyuApp shim between Ryu and Gauge.

```
class faucet.gauge.EventGaugeReconfigure  
Bases: ryu.controller.event.EventBase
```

Event sent to Gauge to cause config reload.

```
class faucet.gauge.Gauge(*args, **kwargs)  
Bases: ryu.base.app_manager.RyuApp
```

Ryu app for polling Faucet controlled datapaths for stats/state.

It can poll multiple datapaths. The configuration files for each datapath should be listed, one per line, in the file set as the environment variable GAUGE\_CONFIG. It logs to the file set as the environment variable GAUGE\_LOG,

```
OFP_VERSIONS = [4]
```

```
exc_logname = 'gauge.exception'
```

```
flow_stats_reply_handler(ryu_event)
```

Handle flow stats reply event.

```
Parameters ryu_event (ryu.controller.event.EventReplyBase) – flow stats  
event.
```

```
handler_connect_or_disconnect(ryu_event)
```

Handle DP dis/connect.

```
Parameters ryu_event (ryu.controller.event.EventReplyBase) – DP recon-  
nection.
```

```
handler_reconnect(ryu_event)
```

Handle a DP reconnection event.

```
Parameters ryu_event (ryu.controller.event.EventReplyBase) – DP recon-  
nection.
```

```
logname = 'gauge'
```

```
port_stats_reply_handler(ryu_event)
```

Handle port stats reply event.

```
Parameters ryu_event (ryu.controller.event.EventReplyBase) – port stats  
event.
```

```
port_status_handler(ryu_event)
```

Handle port status change event.

```
Parameters ryu_event (ryu.controller.event.EventReplyBase) – port status  
change event.
```

```

reload_config(_)
    Handle request for Gauge config reload.

signal_handler(sigid, _)
    Handle signal and cause config reload.

    Parameters sigid (int) – signal received.

start()

```

## faucet.gauge\_influx module

Library for interacting with InfluxDB.

```

class faucet.gauge_influx.GaugeFlowTableInfluxDBLogger(conf, logname, prom_client)
    Bases:      faucet.gauge_pollers.GaugeFlowTablePoller,   faucet.gauge_influx.
                InfluxShipper

```

### Example

```

> use faucet
Using database faucet
> show series where table_id = '0' and in_port = '2'
key
---
flow_byte_count,dp_name=windscale-faucet-1,eth_type=2048,in_port=2,ip_proto=17,
˓→priority=9099,table_id=0,udp_dst=53
flow_byte_count,dp_name=windscale-faucet-1,eth_type=2048,in_port=2,ip_proto=6,
˓→priority=9098,table_id=0,tcp_dst=53
flow_byte_count,dp_name=windscale-faucet-1,in_port=2,priority=9097,table_id=0
flow_packet_count,dp_name=windscale-faucet-1,eth_type=2048,in_port=2,ip_proto=17,
˓→priority=9099,table_id=0,udp_dst=53
flow_packet_count,dp_name=windscale-faucet-1,eth_type=2048,in_port=2,ip_proto=6,
˓→priority=9098,table_id=0,tcp_dst=53
flow_packet_count,dp_name=windscale-faucet-1,in_port=2,priority=9097,table_id=0
> select * from flow_byte_count where table_id = '0' and in_port = '2' and ip_
˓→proto = '17' and time > now() - 5m
name: flow_byte_count
time                  arp_tpa dp_name          eth_dst eth_src eth_type icmpv6_
˓→type in_port ip_proto ipv4_dst ipv6_dst priority table_id tcp_dst udp_dst value_
˓→vlan_vid
-----
˓→----- ----- ----- ----- ----- ----- ----- ----- ----- ----- ----- -----
˓→----- ----- ----- ----- ----- ----- ----- ----- ----- ----- ----- ----- -----
1501154797000000000           windscale-faucet-1          2048          9414
˓→ 2      17          9099      0          53
1501154857000000000           windscale-faucet-1          2048          10554
˓→ 2      17          9099      0          53
1501154917000000000           windscale-faucet-1          2048          10554
˓→ 2      17          9099      0          53
1501154977000000000           windscale-faucet-1          2048          12164
˓→ 2      17          9099      0          53
1501155037000000000           windscale-faucet-1          2048          12239
˓→ 2      17          9099      0          53

```

**update**(*rcv\_time, dp\_id, msg*)

```
class faucet.gauge_influx.GaugePortStateInfluxDBLogger(conf, logname, prom_client)
Bases: faucet.gauge_pollers.GaugePortStateBaseLogger, faucet.gauge_influx.
InfluxShipper
```

### Example

```
> use faucet
Using database faucet
> precision rfc3339
> select * from port_state_reason where port_name = 'port1.0.1' order by time_‐
‐desc limit 10;
name: port_state_reason
-----
time          dp_name      port_name      value
2017-02-21T02:12:29Z  windscale-faucet-1  port1.0.1    2
2017-02-21T02:12:25Z  windscale-faucet-1  port1.0.1    2
2016-07-27T22:05:08Z  windscale-faucet-1  port1.0.1    2
2016-05-25T04:33:00Z  windscale-faucet-1  port1.0.1    2
2016-05-25T04:32:57Z  windscale-faucet-1  port1.0.1    2
2016-05-25T04:31:21Z  windscale-faucet-1  port1.0.1    2
2016-05-25T04:31:18Z  windscale-faucet-1  port1.0.1    2
2016-05-25T04:27:07Z  windscale-faucet-1  port1.0.1    2
2016-05-25T04:27:04Z  windscale-faucet-1  port1.0.1    2
2016-05-25T04:24:53Z  windscale-faucet-1  port1.0.1    2
```

`update(rcv_time, dp_id, msg)`

```
class faucet.gauge_influx.GaugePortStatsInfluxDBLogger(conf, logname, prom_client)
Bases: faucet.gauge_pollers.GaugePortStatsPoller, faucet.gauge_influx.
InfluxShipper
```

Periodically sends a port stats request to the datapath and parses and outputs the response.

### Example

```
> use faucet
Using database faucet
> show measurements
name: measurements
-----
bytes_in
bytes_out
dropped_in
dropped_out
errors_in
packets_in
packets_out
port_state_reason
> precision rfc3339
> select * from packets_out where port_name = 'port1.0.1' order by time desc_‐
‐limit 10;
name: packets_out
-----
time          dp_name      port_name      value
2017-03-06T05:21:42Z  windscale-faucet-1  port1.0.1    76083431
```

2017-03-06T05:21:33Z	windscale-faucet-1	port1.0.1	76081172
2017-03-06T05:21:22Z	windscale-faucet-1	port1.0.1	76078727
2017-03-06T05:21:12Z	windscale-faucet-1	port1.0.1	76076612
2017-03-06T05:21:02Z	windscale-faucet-1	port1.0.1	76074546
2017-03-06T05:20:52Z	windscale-faucet-1	port1.0.1	76072730
2017-03-06T05:20:42Z	windscale-faucet-1	port1.0.1	76070528
2017-03-06T05:20:32Z	windscale-faucet-1	port1.0.1	76068211
2017-03-06T05:20:22Z	windscale-faucet-1	port1.0.1	76065982
2017-03-06T05:20:12Z	windscale-faucet-1	port1.0.1	76063941

```

update (recv_time, dp_id, msg)

class faucet.gauge_influx.InfluxShipper
Bases: object

Convenience class for shipping values to InfluxDB.

Inheritors must have a WatcherConf object as conf.

conf = None

logger = None

static make_point (tags, recv_time, stat_name, stat_val)
    Make an InfluxDB point.

make_port_point (dp_name, port_name, recv_time, stat_name, stat_val)
    Make an InfluxDB point about a port measurement.

ship_error_prefix = 'error shipping points: '
ship_points (points)
    Make a connection to InfluxDB and ship points.

```

## faucet.gauge\_nsodbc module

Library for interacting with ODBC databases.

```

class faucet.gauge_nsodbc.GaugeFlowTableDBLogger (conf, logname, prom_client)
Bases:      faucet.gauge_pollers.GaugeFlowTablePoller,   faucet.gauge_nsodbc.
GaugeNsODBC

Periodically dumps the current datapath flow table to ODBC DB.

update (recv_time, dp_id, msg)

class faucet.gauge_nsodbc.GaugeNsODBC
Bases: object

Helper class for NSODBC operations

Inheritors must have a WatcherConf object as conf.

conf = None

conn = None

conn_string = None

db_update_counter = None

flow_database = None

refresh_flowdb ()

```

```
refresh_switchdb()
setup()
switch_database = None
```

## faucet.gauge\_pollers module

Library for polling dataplanes for statistics.

```
class faucet.gauge_pollers.GaugeFlowTablePoller(conf, logname, prom_client)
Bases: faucet.gauge_pollers.GaugeThreadPoller
```

Periodically dumps the current datapath flow table as a yaml object.

Includes a timestamp and a reference (\$DATAPATHNAME-flowtables). The flow table is dumped as an OF-FlowStatsReply message (in yaml format) that matches all flows.

```
no_response()
```

```
send_req()
```

```
class faucet.gauge_pollers.GaugePoller(conf, logname, prom_client)
```

Bases: object

Abstraction for a poller for statistics.

```
static no_response()
```

Called when a polling cycle passes without receiving a response.

```
report_dp_status(dp_status)
```

Report DP status.

```
static running()
```

Return True if the poller is running.

```
static send_req()
```

Send a stats request to a datapath.

```
static start(_ryudp)
```

Start the poller.

```
static stop()
```

Stop the poller.

```
update(rcv_time, dp_id, msg)
```

Handle the responses to requests.

Called when a reply to a stats request sent by this object is received by the controller.

It should acknowledge the receipt by setting self.reply\_pending to false.

### Parameters

- **rcv\_time** – the time the response was received
- **dp\_id** – DP ID
- **msg** – the stats reply message

```
class faucet.gauge_pollers.GaugePortStateBaseLogger(conf, logname, prom_client)
Bases: faucet.gauge_pollers.GaugePoller
```

Abstraction for port state poller.

**static no\_response()**

Called when a polling cycle passes without receiving a response.

**static send\_req()**

Send a stats request to a datapath.

**class faucet.gauge\_pollers.GaugePortStatsPoller(conf, logname, prom\_client)**

Bases: *faucet.gauge\_pollers.GaugeThreadPoller*

Periodically sends a port stats request to the datapath and parses and outputs the response.

**no\_response()****send\_req()****class faucet.gauge\_pollers.GaugeThreadPoller(conf, logname, prom\_client)**

Bases: *faucet.gauge\_pollers.GaugePoller*

A ryu thread object for sending and receiving OpenFlow stats requests.

The thread runs in a loop sending a request, sleeping then checking a response was received before sending another request.

The methods send\_req, update and no\_response should be implemented by subclasses.

**static no\_response()**

Called when a polling cycle passes without receiving a response.

**running()****static send\_req()**

Send a stats request to a datapath.

**start(ryudp)****stop()****faucet.gauge\_prom module**

Prometheus for Gauge.

**class faucet.gauge\_prom.GaugePortStatsPrometheusPoller(conf, logger, prom\_client)**

Bases: *faucet.gauge\_prom.GaugePortStatsPoller*

Exports port stats to Prometheus.

**update(rcv\_time, dp\_id, msg)****class faucet.gauge\_prom.GaugePrometheusClient**

Bases: *faucet.prom\_client.PromClient*

Wrapper for Prometheus client that is shared between all pollers.

**metrics = {}**

**faucet.meter module**

Configure meters.

**class faucet.meter.Meter(\_id, dp\_id, conf)**

Bases: *faucet.conf.Conf*

Implement FAUCET configuration for an OpenFlow meter.

```
defaults = {'meter_id': None, 'entry': None}
defaults_type = {'meter_id': <class 'int'>, 'entry': <class 'dict'>}
entry = None
entry_msg = None
meter_id = None
name = None
```

## faucet.nsodbc module

This module exposes an api to deal with db operations on no-sql databases. Currently couchdb support is included.

**class faucet.nsodbc.ConnectionCouch (conn, credentials)**

Bases: object

Connection class.

This class is specific to couchdb operations. For others a new class will be needed (following same standards)

**connected\_databases ()**

Return the connected databases of this connection

**create (db\_name)**

Create a database. If the database exists, return the same and send a True flag. This way, a connection object will only be created once.

**delete (db\_name)**

Delete database specified in the parameter

**class faucet.nsodbc.DatabaseCouch (database)**

Bases: object

Database specific class exposing the API.

**create\_view (design, views)**

This is a couchdb functionality. Helps in creating views needed for querying the database. Input: Design name, view definition

**delete\_doc (doc\_id)**

Delete document based on the doc id

**get\_docs (view\_url, key)**

Select docs

A view url is used as select query with the key as a where condition

**insert\_update\_doc (doc, update\_key=’’)**

Insert or update a document For updating, a key has to be provided against which a document will be updated

**class faucet.nsodbc.NsOdbc**

Bases: object

An abstraction layer to make api calls to a non relational database.

Currently the API provided is: connect create get\_doc insert\_update\_doc delete\_doc

**connect (\*conn\_string, \*\*kwargs)**

Returns a connection object required for further operations Input: connection string or connection parameters Returns: connection object

```

get_attributes()
    Returns API version

faucet.nsodbc.init_flow_db(flow_database)
    Initialize/Refresh flow database

    Parameters flow_database –

faucet.nsodbc.init_switch_db(switch_database)
    Initialize/refresh switch database

    Parameters switch_database –

faucet.nsodbc.nsodbc_factory()
    factory method to consume the API

faucet.nsodbc.todict(conn_string, kwargs)
    Converts the input connection string into a dictionary.

Assumption: Connection string is of the format ‘driver=couchdb;server=localhost;uid=database_uid;pwd=database_pwd’

```

## faucet.port module

Port configuration.

```

class faucet.port.Port(_id, dp_id, conf=None)
    Bases: faucet.conf Conf

    Stores state for ports, including the configuration.

    acl_in = None
    check_config()
    defaults = {'mirror_destination': False, 'stack': None, 'lacp': 0, 'max_hosts': 25}
    defaults_types = {'mirror_destination': <class 'bool'>, 'stack': <class 'dict'>, 'lacp': <class 'int'>, 'max_hosts': <class 'int'>}
    dp_id = None
    dyn_lacp_up = None
    dyn_lacp_updated_time = None
    dyn_last_ban_time = None
    dyn_last_lacp_pkt = None
    dyn_learn_ban_count = 0
    dyn_phys_up = False
    enabled = None
    finalize()
    hairpin = None
    hosts (vlans=None)
        Return all hosts this port has learned (on all or specified VLANs).

    loop_protect = None
    max_hosts = None
    mirror = None

```

```
mirror_destination = None
name = None
native_vlan = None
number = None
permanent_learn = None
running()
set_defaults()
stack = {}
tagged_vlans = []
to_conf()
unicast_flood = None
vlans()
Return list of all VLANs this port is in.
```

## faucet.prom\_client module

Implement Prometheus client.

```
class faucet.prom_client.PromClient
Bases: object
Prometheus client.

REQUIRED_LABELS = ['dp_id', 'dp_name']
running = False
start(prom_port, prom_addr)
Start webserver if not already running.
```

## faucet.router module

Configure routing between VLANs.

```
class faucet.router.Router(_id, dp_id, conf=None)
Bases: faucet.conf.Config

Implement FAUCET configuration for a router.

check_config()
defaults = {'vlans': None}
defaults_type = {'vlans': <class 'list'>}
vlans = None
```

## faucet.tfm\_pipeline module

Parse JSON for TFM based table config.

```
class faucet.tfm_pipeline.LoadRyuTables (cfgpath, pipeline_conf)
    Bases: object
        load_tables ()

class faucet.tfm_pipeline.OpenflowToRyuTranslator (cfgpath, pipeline_conf)
    Bases: object
        create_ryu_structure ()
```

## faucet.valve module

Implementation of Valve learning layer 2/3 switch.

```
class faucet.valve.ArubaValve (dp, logname, notifier)
    Bases: faucet.valve.TfmValve
        Valve implementation that uses OpenFlow send table features messages.

        DEC_TTL = False
        PIPELINE_CONF = 'aruba_pipeline.json'

class faucet.valve.TfmValve (dp, logname, notifier)
    Bases: faucet.valve.Valve
        Valve implementation that uses OpenFlow send table features messages.

        PIPELINE_CONF = 'tfm_pipeline.json'
        SKIP_VALIDATION_TABLES = ()
        switch_features (msg)

class faucet.valve.Valve (dp, logname, notifier)
    Bases: object
        Generates the messages to configure a datapath as a l2 learning switch.

        Vendor specific implementations may require sending configuration flows. This can be achieved by inheriting from this class and overwriting the function switch_features.

        DEC_TTL = True
        L3 = False
        add_route (vlan, ip_gw, ip_dst)
            Add route to VLAN routing table.

        advertise ()
            Called periodically to advertise services (eg. IPv6 RAs).

        base_prom_labels = None
        control_plane_handler (pkt_meta)
            Handle a packet probably destined to FAUCET's route managers.

            For example, next hop resolution or ICMP echo requests.

            Parameters pkt_meta (PacketMeta) – packet for control plane.
```

**Returns** OpenFlow messages, if any.

**Return type** list

**datapath\_connect** (*discovered\_up\_port\_nums*)

Handle Ryu datapath connection event and provision pipeline.

**Parameters** **discovered\_up\_port\_nums** (*list*) – datapath ports that are up as ints.

**Returns** OpenFlow messages to send to datapath.

**Return type** list

**datapath\_disconnect** ()

Handle Ryu datapath disconnection event.

**del\_route** (*vlan, ip\_dst*)

Delete route from VLAN routing table.

**flow\_timeout** (*table\_id, match*)

**get\_config\_dict** ()

**lacp\_down** (*port*)

**lacp\_handler** (*pkt\_meta*)

Handle a LACP packet.

We are a currently a passive, non-aggregateable LACP partner.

**Parameters** **pkt\_meta** ([PacketMeta](#)) – packet for control plane.

**Returns** OpenFlow messages, if any.

**Return type** list

**lacp\_up** (*port*)

**ofchannel\_log** (*ofmsgs*)

Log OpenFlow messages in text format to debugging log.

**parse\_rcv\_packet** (*in\_port, vlan\_vid, eth\_type, data, orig\_len, pkt, eth\_pkt*)

Parse a received packet into a PacketMeta instance.

**Parameters**

- **in\_port** (*int*) – port packet was received on.
- **vlan\_vid** (*int*) – VLAN VID of port packet was received on.
- **eth\_type** (*int*) – Ethernet type of packet.
- **data** (*bytes*) – Raw packet data.
- **orig\_len** (*int*) – Original length of packet.
- **pkt** (*ryu.lib.packet.packet*) – parsed packet received.
- **ekt\_pkt** (*ryu.lib.packet.ethernet*) – parsed Ethernet header.

**Returns** PacketMeta instance.

**port\_add** (*port\_num*)

Handle addition of a single port.

**Parameters** **port\_num** (*list*) – list of port numbers.

**Returns** OpenFlow messages, if any.

**Return type** list

**port\_delete** (*port\_num*)  
**port\_status\_handler** (*port\_no, reason, port\_status*)  
**ports\_add** (*port\_nums, cold\_start=False*)  
Handle the addition of ports.

#### Parameters

- **port\_num** (*list*) – list of port numbers.
- **cold\_start** (*bool*) – True if configuring datapath from scratch.

**Returns** OpenFlow messages, if any.

**Return type** list

**ports\_delete** (*port\_nums*)  
Handle the deletion of ports.

**Parameters** **port\_nums** (*list*) – list of port numbers.

**Returns** OpenFlow messages, if any.

**Return type** list

**recv\_packet** (*other\_valves, pkt\_meta*)  
Handle a packet from the dataplane (eg to re/learn a host).

The packet may be sent to us also in response to FAUCET initiating IPv6 neighbor discovery, or ARP, to resolve a nexthop.

#### Parameters

- **other\_valves** (*list*) – all Valves other than this one.
- **pkt\_meta** ([PacketMeta](#)) – packet for control plane.

**Returns** OpenFlow messages, if any.

**Return type** list

**recent\_ofmsgs** = <[queue.Queue](#) object>  
**reload\_config** (*new\_dp*)  
Reload configuration *new\_dp*.

#### Following config changes are currently supported:

- Port config: support all available configs (e.g. native\_vlan, acl\_in) & change operations (add, delete, modify) a port
- ACL config: support any modification, currently reload all rules belonging to an ACL
- VLAN config: enable, disable routing, etc...

**Parameters** **new\_dp** ([DP](#)) – new dataplane configuration.

**Returns** *cold\_start* (*bool*): whether cold starting. *ofmsgs* (*list*): OpenFlow messages.

**Return type** tuple of

**resolve\_gateways** ()  
Call route managers to re/resolve gateways.

**Returns** OpenFlow messages, if any.

**Return type** list

**state\_expire()**

Expire controller caches/state (e.g. hosts learned).

Expire state from the host manager only; the switch does its own flow expiry.

**Returns** OpenFlow messages, if any.

**Return type** list

**switch\_features(\_msg)**

Send configuration flows necessary for the switch implementation.

**Parameters** **msg** (*OFPSwitchFeatures*) – msg sent from switch.

Vendor specific configuration should be implemented here.

**update\_config\_metrics(metrics)**

Update gauge/metrics for configuration.

**Parameters** **metrics** (*FaucetMetrics*) – container of Prometheus metrics.

**update\_metrics(metrics)**

Update Gauge/metrics.

**Parameters** **metrics** (*FaucetMetrics* or *None*) – container of Prometheus metrics.

**class faucet.valve.ValveLogger(logger, dp\_id)**

Bases: object

**debug(log\_msg)**

**error(log\_msg)**

**info(log\_msg)**

**warning(log\_msg)**

**faucet.valve.valve\_factory(dp)**

Return a Valve object based dp's hardware configuration field.

**Parameters** **dp** (*DP*) – DP instance with the configuration for this Valve.

## faucet.valve\_acl module

Compose ACLs on ports.

**faucet.valve\_acl.build\_acl\_entry(rule\_conf, acl\_allow\_inst, meters, port\_num=None, vlan\_vid=None)**

**faucet.valve\_acl.build\_acl\_ofmsgs(acls, acl\_table, acl\_allow\_inst, highest\_priority, meters, exact\_match, port\_num=None, vlan\_vid=None)**

**faucet.valve\_acl.build\_output\_actions(output\_dict)**

Implement actions to alter packet/output.

**faucet.valve\_acl.push\_vlan(vlan\_vid)**

Push a VLAN tag with optional selection of eth type.

**faucet.valve\_acl.rewrite\_vlan(output\_dict)**

Implement actions to rewrite VLAN headers.

## faucet.valve\_flood module

Manage flooding to ports on VLANs.

```
class faucet.valve_flood.ValveFloodManager(flood_table, flood_priority, use_group_table,
                                             groups)
```

Bases: object

Implement dataplane based flooding for standalone dataplanes.

```
FLOOD_DSTS = ((True, None, None), (False, '01:80:c2:00:00:00', 'ff:ff:ff:00:00:00'), (
```

```
build_flood_rules(vlan, modify=False)
```

Add flows to flood packets to unknown destinations on a VLAN.

```
static edge_learn_port(_other_valves, pkt_meta)
```

Possibly learn a host on a port.

### Parameters

- **other\_valves** (*list*) – All Valves other than this one.
- **pkt\_meta** ([PacketMeta](#)) – PacketMeta instance for packet received.

**Returns** port to learn host on.

```
class faucet.valve_flood.ValveFloodStackManager(flood_table, flood_priority,
                                                 use_group_table, groups, stack,
                                                 stack_ports, dp_shortest_path_to_root,
                                                 shortest_path_port)
```

Bases: *faucet.valve\_flood.ValveFloodManager*

Implement dataplane based flooding for stacked dataplanes.

```
build_flood_rules(vlan, modify=False)
```

Add flows to flood packets to unknown destinations on a VLAN.

```
edge_learn_port(other_valves, pkt_meta)
```

Possibly learn a host on a port.

### Parameters

- **other\_valves** (*list*) – All Valves other than this one.
- **pkt\_meta** ([PacketMeta](#)) – PacketMeta instance for packet received.

**Returns** port to learn host on, or None.

## faucet.valve\_host module

Manage host learning on VLANs.

```
class faucet.valve_host.ValveHostFlowRemovedManager(logger, ports, vlans,
                                                      eth_src_table, eth_dst_table,
                                                      learn_timeout, learn_jitter,
                                                      learn_ban_timeout,
                                                      low_priority, host_priority)
```

Bases: *faucet.valve\_host.ValveHostManager*

Trigger relearning on flow removed notifications.

---

**Note:** not currently reliable.

---

**expire\_hosts\_from\_vlan** (*\_vlan*, *\_now*)

**flow\_timeout** (*table\_id*, *match*)

**learn\_host\_timeouts** (*port*)

Calculate flow timeouts for learning on a port.

**class** faucet.valve\_host.**ValveHostManager** (*logger*, *ports*, *vlans*, *eth\_src\_table*, *eth\_dst\_table*,  
*learn\_timeout*, *learn\_jitter*, *learn\_ban\_timeout*,  
*low\_priority*, *host\_priority*)

Bases: object

**ban\_rules** (*pkt\_meta*)

Limit learning to a maximum configured on this port/VLAN.

**Parameters** **pkt\_meta** – PacketMeta instance.

**Returns** OpenFlow messages, if any.

**Return type** list

**build\_port\_out\_inst** (*vlan*, *port*, *port\_number=None*)

Return instructions to output a packet on a given port.

**delete\_host\_from\_vlan** (*eth\_src*, *vlan*)

Delete a host from a VLAN.

**expire\_hosts\_from\_vlan** (*vlan*, *now*)

Expire hosts from VLAN cache.

**flow\_timeout** (*\_table\_id*, *\_match*)

**learn\_host\_on\_vlan\_port\_flows** (*port*, *vlan*, *eth\_src*, *delete\_existing*, *src\_rule\_idle\_timeout*,  
*src\_rule\_hard\_timeout*, *dst\_rule\_idle\_timeout*)

Return flows that implement learning a host on a port.

**learn\_host\_on\_vlan\_ports** (*port*, *vlan*, *eth\_src*, *delete\_existing=True*)

Learn a host on a port.

**learn\_host\_timeouts** (*port*)

Calculate flow timeouts for learning on a port.

## faucet.valve\_of module

Utility functions to parse/create OpenFlow messages.

**faucet.valve\_of.apply\_actions** (*actions*)

Return instruction that applies action list.

**Parameters** **actions** (*list*) – list of OpenFlow actions.

**Returns** instruction of actions.

**Return type** ryu.ofproto.ofproto\_v1\_3\_parser.OFPIInstruction

**faucet.valve\_of.apply\_meter** (*meter\_id*)

Return instruction to apply a meter.

**faucet.valve\_of.barrier** ()

Return OpenFlow barrier request.

**Returns** barrier request.

**Return type** ryu.ofproto.ofproto\_v1\_3\_parser.OFPBarrierRequest

```
faucet.valve_of.bucket (weight=0, watch_port=4294967295, watch_group=4294967295, actions=None)
```

Return a group action bucket with provided actions.

```
faucet.valve_of.build_match_dict (in_port=None, vlan=None, eth_type=None, eth_src=None, eth_dst=None, eth_dst_mask=None, ipv6_nd_target=None, icmpv6_type=None, nw_proto=None, nw_src=None, nw_dst=None)
```

```
faucet.valve_of.controller_pps_meteradd (datapath=None, pps=0)
```

Add a PPS meter towards controller.

```
faucet.valve_of.controller_pps_meterdel (datapath=None)
```

Delete a PPS meter towards controller.

```
faucet.valve_of.dec_ip_ttl()
```

Return OpenFlow action to decrement IP TTL.

**Returns** decrement IP TTL.

**Return type** ryu.ofproto.ofproto\_v1\_3\_parser.OFPActionDecNwTtl

```
faucet.valve_of.desc_stats_request (datapath=None)
```

Query switch description.

```
faucet.valve_of.devvid_present (vid)
```

Return VLAN VID without VID\_PRESENT flag set.

**Parameters** `vid` (`int`) – VLAN VID with VID\_PRESENT.

**Returns** VLAN VID.

**Return type** int

```
faucet.valve_of.faucet_async (datapath=None)
```

Return async message config for FAUCET.

```
faucet.valve_of.faucet_config (datapath=None)
```

Return switch config for FAUCET.

```
faucet.valve_of.flood_tagged_port_outputs (ports, in_port, exclude_ports=None)
```

Return list of actions necessary to flood to list of tagged ports.

```
faucet.valve_of.flood_untagged_port_outputs (ports, in_port, exclude_ports=None)
```

Return list of actions necessary to flood to list of untagged ports.

```
faucet.valve_of.flowmod (cookie, command, table_id, priority, out_port, out_group, match_fields, inst, hard_timeout, idle_timeout, flags=0)
```

```
faucet.valve_of.gauge_async (datapath=None)
```

Return async message config for Gauge.

```
faucet.valve_of.goto_table (table)
```

Return instruction to goto table.

**Parameters** `table` (`ValveTable`) – table to goto.

**Returns** goto instruction.

**Return type** ryu.ofproto.ofproto\_v1\_3\_parser.OFPIInstruction

```
faucet.valve_of.group_act (group_id)
```

Return an action to run a group.

```
faucet.valve_of.group_flood_buckets(ports, untagged)
faucet.valve_of.groupadd(datapath=None, type_=0, group_id=0, buckets=None)
    Add a group.

faucet.valve_of.groupadd_ff(datapath=None, group_id=0, buckets=None)
    Add a fast failover group.

faucet.valve_of.groupdel(datapath=None, group_id=4294967292)
    Delete a group (default all groups).

faucet.valve_of.groupmod(datapath=None, type_=0, group_id=0, buckets=None)
    Modify a group.

faucet.valve_of.groupmod_ff(datapath=None, group_id=0, buckets=None)
    Modify a fast failover group.

faucet.valve_of.ignore_port(port_num)
    Return True if FAUCET should ignore this port.

Parameters port_num (int) – switch port.

Returns True if FAUCET should ignore this port.

Return type bool

faucet.valve_of.is_flowdel(ofmsg)
    Return True if flow message is a FlowMod and a delete.

Parameters ofmsg – ryu.ofproto.ofproto_v1_3_parser message.

Returns True if is a FlowMod delete/strict.

Return type bool

faucet.valve_of.is_flowmod(ofmsg)
    Return True if flow message is a FlowMod.

Parameters ofmsg – ryu.ofproto.ofproto_v1_3_parser message.

Returns True if is a FlowMod

Return type bool

faucet.valve_of.is_groupadd(ofmsg)
    Return True if OF message is a GroupMod and command is add.

Parameters ofmsg – ryu.ofproto.ofproto_v1_3_parser message.

Returns True if is a GroupMod add

Return type bool

faucet.valve_of.is_groupdel(ofmsg)
    Return True if OF message is a GroupMod and command is delete.

Parameters ofmsg – ryu.ofproto.ofproto_v1_3_parser message.

Returns True if is a GroupMod delete

Return type bool

faucet.valve_of.is_groupmod(ofmsg)
    Return True if OF message is a GroupMod.

Parameters ofmsg – ryu.ofproto.ofproto_v1_3_parser message.

Returns True if is a GroupMod
```

**Return type** bool

```
faucet.valve_of.match(match_fields)
    Return OpenFlow matches from dict.
```

**Parameters** `match_fields` (`dict`) – match fields and values.

**Returns** matches.

**Return type** ryu.ofproto.ofproto\_v1\_3\_parser.OFPMatch

```
faucet.valve_of.match_from_dict(match_dict)
```

```
faucet.valve_of.meteradd(meter_conf)
```

Add a meter based on YAML configuration.

```
faucet.valve_of.meterdel(datapath=None, meter_id=4294967295)
```

Delete a meter (default all meters).

```
faucet.valve_of.output_controller(max_len=128)
```

Return OpenFlow action to packet in to the controller.

**Parameters** `max_len` (`int`) – max number of bytes from packet to output.

**Returns** packet in action.

**Return type** ryu.ofproto.ofproto\_v1\_3\_parser.OFPActionOutput

```
faucet.valve_of.output_in_port()
```

Return OpenFlow action to output out input port.

**Returns** ryu.ofproto.ofproto\_v1\_3\_parser.OFPActionOutput.

```
faucet.valve_of.output_port(port_num, max_len=0)
```

Return OpenFlow action to output to a port.

**Parameters**

- `port_num` (`int`) – port to output to.
- `max_len` (`int`) – maximum length of packet to output (default no maximum).

**Returns** output to port action.

**Return type** ryu.ofproto.ofproto\_v1\_3\_parser.OFPActionOutput

```
faucet.valve_of.packetout(port_num, data)
```

Return OpenFlow action to packet out to dataplane from controller.

**Parameters**

- `port_num` (`int`) – port to output to.
- `data` (`str`) – raw packet to output.

**Returns** packet out action.

**Return type** ryu.ofproto.ofproto\_v1\_3\_parser.OFPActionOutput

```
faucet.valve_of.pop_vlan()
```

Return OpenFlow action to pop outermost Ethernet 802.1Q VLAN header.

**Returns** Pop VLAN.

**Return type** ryu.ofproto.ofproto\_v1\_3\_parser.OFPActionPopVlan

```
faucet.valve_of.push_vlan_act(vlan_vid, eth_type=33024)
```

Return OpenFlow action list to push Ethernet 802.1Q header with VLAN VID.

**Parameters** `vid`(*int*) – VLAN VID

**Returns** actions to push 802.1Q header with VLAN VID set.

**Return type** list

`faucet.valve_of.set_ether_dst(eth_dst)`

Return action to set destination Ethernet MAC address.

**Parameters** `eth_src`(*str*) – destination Ethernet MAC address.

**Returns** set field action.

**Return type** `ryu.ofproto.ofproto_v1_3_parser.OFPActionSetField`

`faucet.valve_of.set_ether_src(eth_src)`

Return action to set source Ethernet MAC address.

**Parameters** `eth_src`(*str*) – source Ethernet MAC address.

**Returns** set field action.

**Return type** `ryu.ofproto.ofproto_v1_3_parser.OFPActionSetField`

`faucet.valve_of.set_vlan_vid(vlan_vid)`

Set VLAN VID with VID\_PRESENT flag set.

**Parameters** `vid`(*int*) – VLAN VID

**Returns** set VID with VID\_PRESENT.

**Return type** `ryu.ofproto.ofproto_v1_3_parser.OFPActionSetField`

`faucet.valve_of.table_features(body)`

`faucet.valve_of.valve_flowreorder(input_ofmsgs)`

Reorder flows for better OFA performance.

`faucet.valve_of.valve_match_vid(value)`

`faucet.valve_of.vlan_present(vid)`

Return VLAN VID with VID\_PRESENT flag set.

**Parameters** `vid`(*int*) – VLAN VID

**Returns** VLAN VID with VID\_PRESENT.

**Return type** int

## `faucet.valve_packet` module

Utility functions for parsing and building Ethernet packet/contents.

`class faucet.valve_packet.PacketMeta(data, orig_len, pkt, eth_pkt, port, valve_vlan, eth_src, eth_dst, eth_type)`

Bases: object

Original, and parsed Ethernet packet metadata.

`ETH_TYPES_PARSERS = {2048: (4, <function ipv4_parseable>, <class 'ryu.lib.packet.ipv4`

`ip_ver()`

Return IP version number.

`packet_complete()`

True if we have the complete packet.

**reparse**(*max\_len*)

Reparse packet using data up to the specified maximum length.

**reparse\_all**()

Reparse packet with all available data.

**reparse\_ip**(*eth\_type*, *payload*=0)

Reparse packet with specified IP header type and optionally payload.

`faucet.valve_packet.arp_reply(vid, eth_src, eth_dst, src_ip, dst_ip)`

Return an ARP reply packet.

**Parameters**

- **vid**(*int or None*) – VLAN VID to use (or None).
- **eth\_src**(*str*) – Ethernet source address.
- **eth\_dst**(*str*) – destination Ethernet MAC address.
- **src\_ip**(*ipaddress.IPv4Address*) – source IPv4 address.
- **dst\_ip**(*ipaddress.IPv4Address*) – destination IPv4 address.

**Returns** serialized ARP reply packet.

**Return type** `ryu.lib.packet.arp`

`faucet.valve_packet.arp_request(vid, eth_src, src_ip, dst_ip)`

Return an ARP request packet.

**Parameters**

- **vid**(*int or None*) – VLAN VID to use (or None).
- **eth\_src**(*str*) – Ethernet source address.
- **src\_ip**(*ipaddress.IPv4Address*) – source IPv4 address.
- **dst\_ip**(*ipaddress.IPv4Address*) – requested IPv4 address.

**Returns** serialized ARP request packet.

**Return type** `ryu.lib.packet.arp`

`faucet.valve_packet.build_pkt_header(vid, eth_src, eth_dst, dl_type)`

Return an Ethernet packet header.

**Parameters**

- **vid**(*int or None*) – VLAN VID to use (or None).
- **eth\_src**(*str*) – source Ethernet MAC address.
- **eth\_dst**(*str*) – destination Ethernet MAC address.
- **dl\_type**(*int*) – EtherType.

**Returns** Ethernet packet with header.

**Return type** `ryu.lib.packet.ethernet`

`faucet.valve_packet.echo_reply(vid, eth_src, eth_dst, src_ip, dst_ip, data)`

Return an ICMP echo reply packet.

**Parameters**

- **vid**(*int or None*) – VLAN VID to use (or None).

- **eth\_src** (*str*) – Ethernet source address.
- **eth\_dst** (*str*) – destination Ethernet MAC address.
- **src\_ip** (*ipaddress.IPv4Address*) – source IPv4 address.
- **dst\_ip** (*ipaddress.IPv4Address*) – destination IPv4 address.

**Returns** serialized ICMP echo reply packet.

**Return type** ryu.lib.packet.icmp

```
faucet.valve_packet.icmpv6_echo_reply(vid, eth_src, eth_dst, src_ip, dst_ip, hop_limit, id_, seq, data)
```

Return IPv6 ICMP echo reply packet.

### Parameters

- **vid** (*int or None*) – VLAN VID to use (or None).
- **eth\_src** (*str*) – source Ethernet MAC address.
- **eth\_dst** (*str*) – destination Ethernet MAC address.
- **src\_ip** (*ipaddress.IPv6Address*) – source IPv6 address.
- **dst\_ip** (*ipaddress.IPv6Address*) – destination IPv6 address.
- **hop\_limit** (*int*) – IPv6 hop limit.
- **id\_** (*int*) – identifier for echo reply.
- **seq** (*int*) – sequence number for echo reply.
- **data** (*str*) – payload for echo reply.

**Returns** Serialized IPv6 ICMP echo reply packet.

**Return type** ryu.lib.packet.ethernet

```
faucet.valve_packet.ip_header_size(eth_type)
```

Return size of a packet header with specified ether type.

```
faucet.valve_packet.ipv4_parseable(ip_header_data)
```

Return True if an IPv4 packet we could parse.

```
faucet.valve_packet.ipv6_link_eth_mcast(dst_ip)
```

Return an Ethernet multicast address from an IPv6 address.

See RFC 2464 section 7.

**Parameters** **dst\_ip** (*ipaddress.IPv6Address*) – IPv6 address.

**Returns** Ethernet multicast address.

**Return type** str

```
faucet.valve_packet.ipv6_solicited_node_from_ucast(ucast)
```

Return IPv6 solicited node multicast address from IPv6 unicast address.

See RFC 3513 section 2.7.1.

**Parameters** **ucast** (*ipaddress.IPv6Address*) – IPv6 unicast address.

**Returns** IPv6 solicited node multicast address.

**Return type** ipaddress.IPv6Address

```
faucet.valve_packet.lacp_reqreply(eth_src, actor_system, actor_key, actor_port,
                                 partner_system, partner_key, partner_port, part-
                                 ner_system_priority, partner_port_priority, part-
                                 ner_state_defaulted, partner_state_expired, part-
                                 ner_state_timeout, partner_state_collecting, part-
                                 ner_state_distributing, partner_state_aggregation, part-
                                 ner_state_synchronization, partner_state_activity)
```

Return a LACP frame.

#### Parameters

- **eth\_src** (*str*) – source Ethernet MAC address.
- **actor\_system** (*str*) – actor system ID (MAC address)
- **actor\_key** (*int*) – actor's LACP key assigned to this port.
- **actor\_port** (*int*) – actor port number.
- **partner\_system** (*str*) – partner system ID (MAC address)
- **partner\_key** (*int*) – partner's LACP key assigned to this port.
- **partner\_port** (*int*) – partner port number.
- **partner\_system\_priority** (*int*) – partner's system priority.
- **partner\_port\_priority** (*int*) – partner's port priority.
- **partner\_state\_defaulted** (*int*) – 1 if partner reverted to defaults.
- **partner\_state\_expired** (*int*) – 1 if partner thinks LACP expired.
- **partner\_state\_timeout** (*int*) – 1 if partner has short timeout.
- **partner\_state\_collecting** (*int*) – 1 if partner receiving on this link.
- **partner\_state\_distributing** (*int*) – 1 if partner transmitting on this link.
- **partner\_state\_aggregation** (*int*) – 1 if partner can aggregate this link.
- **partner\_state\_synchronization** (*int*) – 1 if partner will use this link.
- **partner\_state\_activity** (*int*) – 1 if partner actively sends LACP.

**Returns** Ethernet packet with header.

**Return type** ryu.lib.packet.ethernet

```
faucet.valve_packet.mac_addr_is_unicast(mac_addr)
```

Returns True if mac\_addr is a unicast Ethernet address.

**Parameters** **mac\_addr** (*str*) – MAC address.

**Returns** True if a unicast Ethernet address.

**Return type** bool

```
faucet.valve_packet.mac_byte_mask(mask_bytes=0)
```

Return a MAC address mask with n bytes masked out.

```
faucet.valve_packet.nd_advert(vid, eth_src, eth_dst, src_ip, dst_ip)
```

Return IPv6 neighbor advertisement packet.

#### Parameters

- **vid** (*int or None*) – VLAN VID to use (or None).
- **eth\_src** (*str*) – source Ethernet MAC address.

- **eth\_dst** (*str*) – destination Ethernet MAC address.
- **src\_ip** (*ipaddress.IPv6Address*) – source IPv6 address.
- **dst\_ip** (*ipaddress.IPv6Address*) – destination IPv6 address.

**Returns** Serialized IPv6 neighbor discovery packet.

**Return type** ryu.lib.packet.ethernet

`faucet.valve_packet.nd_request(vid, eth_src, src_ip, dst_ip)`

Return IPv6 neighbor discovery request packet.

**Parameters**

- **vid** (*int or None*) – VLAN VID to use (or None).
- **eth\_src** (*str*) – source Ethernet MAC address.
- **src\_ip** (*ipaddress.IPv6Address*) – source IPv6 address.
- **dst\_ip** (*ipaddress.IPv6Address*) – requested IPv6 address.

**Returns** Serialized IPv6 neighbor discovery packet.

**Return type** ryu.lib.packet.ethernet

`faucet.valve_packet.parse_eth_pkt(pkt)`

Return parsed Ethernet packet.

**Parameters** **pkt** (*ryu.lib.packet.packet*) – packet received from dataplane.

**Returns** Ethernet packet.

**Return type** ryu.lib.packet.ethernet

`faucet.valve_packet.parse_lacp_pkt(pkt)`

Return parsed LACP packet.

**Parameters** **pkt** (*ryu.lib.packet.packet*) – packet received from dataplane.

**Returns** LACP packet.

**Return type** ryu.lib.packet.lacp

`faucet.valve_packet.parse_packet_in_pkt(data, max_len)`

Parse a packet received via packet in from the dataplane.

**Parameters**

- **data** (*bytearray*) – packet data from dataplane.
- **max\_len** (*int*) – max number of packet data bytes to parse.

**Returns** Ethernet packet. int: VLAN VID. int: Ethernet type of packet (inside VLAN)

**Return type** ryu.lib.packet.ethernet

`faucet.valve_packet.parse_vlan_pkt(pkt)`

Return parsed VLAN header.

**Parameters** **pkt** (*ryu.lib.packet.packet*) – packet received from dataplane.

**Returns** VLAN header.

**Return type** ryu.lib.packet.vlan

`faucet.valve_packet.router_advert(_vlan, vid, eth_src, eth_dst, src_ip, dst_ip, vips, pi_flags=6)`

Return IPv6 ICMP echo reply packet.

**Parameters**

- **\_vlan** (`VLAN`) – VLAN instance.
- **vid** (`int or None`) – VLAN VID to use (or None).
- **eth\_src** (`str`) – source Ethernet MAC address.
- **eth\_dst** (`str`) – dest Ethernet MAC address.
- **src\_ip** (`ipaddress.IPv6Address`) – source IPv6 address.
- **vips** (`list`) – prefixes (`ipaddress.IPv6Address`) to advertise.
- **pi\_flags** (`int`) – flags to set in prefix information field (default set A and L)

**Returns** Serialized IPv6 ICMP RA packet.

**Return type** `ryu.lib.packet.ethernet`

**faucet.valve\_route module**

Valve IPv4/IPv6 routing implementation.

```
class faucet.valve_route.NextHop(eth_src, now)
Bases: object
```

Describes a directly connected (at layer 2) nexthop.

```
class faucet.valve_route.ValveIPv4RouteManager(logger, arp_neighbor_timeout,
max_hosts_per_resolve_cycle,
max_host_fib_retry_count,
max_resolve_backoff_time, proactive_learn, dec_ttl, fib_table,
vip_table, eth_src_table, eth_dst_table,
flood_table, route_priority, routers,
use_group_table, groups)
Bases: faucet.valve_route.ValveRouteManager
```

Implement IPv4 RIB/FIB.

```
CONTROL_ETH_TYPES = (2048, 2054)
ETH_TYPE = 2048
ICMP_TYPE = 1
IPV = 4
control_plane_handler(pkt_meta)
```

```
class faucet.valve_route.ValveIPv6RouteManager(logger, arp_neighbor_timeout,
max_hosts_per_resolve_cycle,
max_host_fib_retry_count,
max_resolve_backoff_time, proactive_learn, dec_ttl, fib_table,
vip_table, eth_src_table, eth_dst_table,
flood_table, route_priority, routers,
use_group_table, groups)
Bases: faucet.valve_route.ValveRouteManager
```

Implement IPv6 FIB.

```
CONTROL_ETH_TYPES = (34525, )
```

```

ETH_TYPE = 34525
ICMP_TYPE = 58
IPV = 6
advertise(vlan)
control_plane_handler(pkt_meta)
class faucet.valve_route.ValveRouteManager(logger, arp_neighbor_timeout,
                                         max_hosts_per_resolve_cycle,
                                         max_host_fib_retry_count,
                                         max_resolve_backoff_time, proactive_learn,
                                         dec_ttl, fib_table, vip_table, eth_src_table,
                                         eth_dst_table, flood_table, route_priority,
                                         routers, use_group_table, groups)

```

Bases: object

Base class to implement RIB/FIB.

**CONTROL\_ETH\_TYPES** = None

**ETH\_TYPE** = None

**ICMP\_TYPE** = None

**IPV** = None

**MAX\_LEN** = 128

**add\_faucet\_vip**(*vlan*, *faucet\_vip*)

**add\_host\_fib\_route\_from\_pkt**(*pkt\_meta*)

Add a host FIB route given packet from host.

**Parameters** **pkt\_meta** (`PacketMeta`) – received packet.

**Returns** OpenFlow messages.

**Return type** list

**add\_route**(*vlan*, *ip\_gw*, *ip\_dst*)

Add a route to the RIB.

**Parameters**

- **vlan** (`vlan`) – VLAN containing this RIB.
- **ip\_gw** (`ipaddress.ip_address`) – IP address of nexthop.
- **ip\_dst** (`ipaddress.ip_network`) – destination IP network.

**Returns** OpenFlow messages.

**Return type** list

**advertise**(*vlan*)

**control\_plane\_handler**(*pkt\_meta*)

**del\_route**(*vlan*, *ip\_dst*)

Delete a route from the RIB.

Only one route with this exact destination is supported.

**Parameters**

- **vlan** (`vlan`) – VLAN containing this RIB.

- **ip\_dst** (*ipaddress.ip\_network*) – destination IP network.

**Returns** OpenFlow messages.

**Return type** list

**resolve\_gateways** (*vlan*, *now*)

Re/resolve all gateways.

**Parameters**

- **vlan** (*vlan*) – VLAN containing this RIB/FIB.
- **now** (*float*) – seconds since epoch.

**Returns** OpenFlow messages.

**Return type** list

**resolve\_gw\_on\_vlan** (*vlan*, *faucet\_vip*, *ip\_gw*)

## faucet.valve\_table module

Abstraction of an OF table.

**class** faucet.valve\_table.ValveGroupEntry (*table*, *group\_id*, *buckets*)

Bases: object

Abstraction for a single OpenFlow group entry.

**add()**

Return flows to add this entry to the group table.

**delete()**

Return flow to delete an existing group entry.

**modify()**

Return flow to modify an existing group entry.

**update\_buckets** (*buckets*)

**class** faucet.valve\_table.ValveGroupTable

Bases: object

Wrap access to group table.

**delete\_all()**

Delete all groups.

**entries** = {}

**get\_entry** (*group\_id*, *buckets*)

**static group\_id\_from\_str** (*key\_str*)

Return a group ID based on a string key.

**class** faucet.valve\_table.ValveTable (*table\_id*, *name*, *restricted\_match\_types*, *flow\_cookie*, *no-  
tify\_flow\_removed=False*)

Bases: object

Wrapper for an OpenFlow table.

**flowcontroller** (*match=None*, *priority=None*, *inst=None*, *max\_len=96*)

Add flow outputting to controller.

```
flowdel (match=None, priority=None, out_port=4294967295, strict=False)
    Delete matching flows from a table.

flowdrop (match=None, priority=None, hard_timeout=0)
    Add drop matching flow to a table.

flowmod (match=None, priority=None, inst=None, command=0, out_port=0, out_group=0,
            hard_timeout=0, idle_timeout=0)
    Helper function to construct a flow mod message with cookie.

match (in_port=None, vlan=None, eth_type=None, eth_src=None, eth_dst=None, eth_dst_mask=None,
        ipv6_nd_target=None, icmpv6_type=None, nw_proto=None, nw_src=None, nw_dst=None)
    Compose an OpenFlow match rule.
```

### faucet.valve\_util module

Utility functions for FAUCET.

```
faucet.valve_util.btos (b_str)
    Return byte array/string as string.

faucet.valve_util.dpid_log (dpid)
    Log a DP ID as hex/decimal.

faucet.valve_util.get_bool_setting (name)
    Return True if setting is a non-zero int.

faucet.valve_util.get_logger (logname, logfile, loglevel, propagate)
    Create and return a logger object.

faucet.valve_util.get_setting (name)
    Returns value of specified configuration setting.

faucet.valve_util.get_sys_prefix ()
    Returns an additional prefix for log and configuration files when used in a virtual environment

faucet.valve_util.kill_on_exception (logname)
    decorator to ensure functions will kill ryu when an unhandled exception occurs

faucet.valve_util.stat_config_files (config_hashes)
    Return dict of a subset of stat attributes on config files.
```

### faucet.vlan module

VLAN configuration.

```
class faucet.vlan.HostCacheEntry (eth_src, port, cache_time)
    Bases: object

class faucet.vlan.VLAN (_id, dp_id, conf=None)
    Bases: faucet.conf.Conf

    Contains state for one VLAN, including its configuration.

    acl_in = None
    add_cache_host (eth_src, port, cache_time)
    add_tagged (port)
    add_untagged (port)
```

```

bgp_as = None
bgp_local_address = None
bgp_neighbor_addresses = []
bgp_neighbor_as = None
bgp_neighbour_addresses = []
bgp_neighbour_as = None
bgp_port = None
bgp_routerid = None
bgp_server_addresses = []
cached_host(eth_src)
cached_host_on_port(eth_src, port)
    Return host cache entry if host in cache and on specified port.
cached_hosts_on_port(port)
    Return all hosts learned on a port.
check_config()
clear_cache_hosts_on_port(port)
    Clear all hosts learned on a port.
defaults = {'bgp_neighbour_addresses': [], 'bgp_server_addresses': ['0.0.0.0', '::']}
defaults_types = {'bgp_neighbour_addresses': <class 'list'>, 'bgp_server_addresses':
dp_id = None
dyn_faucet_vips_by_ipv = None
dyn_host_cache = None
dyn_learn_ban_count = 0
dyn_neigh_cache_by_ipv = None
dyn_routes_by_ipv = None
expire_cache_hosts(now, learn_timeout)
    Expire stale host entries.
faucet_mac = None
faucet_vips = None
faucet_vips_by_ipv(ipv)
    Return list of VIPs with specified IP version on this VLAN.
flood_pkt(packet_builder, *args)
flood_ports(configured_ports, exclude_unicast)
from_connected_to_vip(src_ip, dst_ip)
    Return True if src_ip in connected network and dst_ip is a VIP.

```

#### Parameters

- **src\_ip** (*ipaddress.ip\_address*) – source IP.
- **dst\_ip** (*ipaddress.ip\_address*) – destination IP

**Returns** True if local traffic for a VIP.

**get\_ports()**

Return list of all ports on this VLAN.

**hairpin\_ports()**

Return all ports with hairpin enabled.

**host\_cache**

Return host (L2) cache for this VLAN.

**hosts\_count()**

Return number of hosts learned on this VLAN.

**ip\_in\_vip\_subnet(ipa)**

Return faucet\_vip if IP in same IP network as a VIP on this VLAN.

**ips\_in\_vip\_subnet(ips)**

Return True if all IPs are on same subnet as VIP on this VLAN.

**ipvs()**

Return list of IP versions configured on this VLAN.

**is\_faucet\_vip(ipa)**

Return True if IP is a VIP on this VLAN.

**lags()**

Return dict of LAGs mapped to member ports.

**max\_hosts = None**

**mirror\_destination\_ports()**

Return list of ports that are mirrored to, on this VLAN.

**mirrored\_ports()**

Return list of ports that are mirrored on this VLAN.

**name = None**

**neigh\_cache\_by\_ipv(ipv)**

Return neighbor cache for specified IP version on this VLAN.

**port\_is\_tagged(port)**

Return True if port number is an tagged port on this VLAN.

**port\_is\_untagged(port)**

Return True if port number is an untagged port on this VLAN.

**proactive\_arp\_limit = None**

**proactive\_nd\_limit = None**

**reset\_host\_cache()**

**routes = None**

**routes\_by\_ipv(ipv)**

Return route table for specified IP version on this VLAN.

**set\_defaults()**

**tagged = None**

**tagged\_flood\_ports(exclude\_unicast)**

**unicast\_flood = None**

---

```
untagged = None
untagged_flood_ports (exclude_unicast)
vid = None
static vid_valid(vid)
    Return True if VID valid.
```

## faucet.watcher module

Gauge watcher implementations.

```
class faucet.watcher.GaugeFlowTableLogger (conf, logname, prom_client)
```

Bases: *faucet.gauge\_pollers.GaugeFlowTablePoller*

Periodically dumps the current datapath flow table as a yaml object.

Includes a timestamp and a reference (\$DATAPATHNAME-flowtables). The flow table is dumped as an OF-FlowStatsReply message (in yaml format) that matches all flows.

optionally the output can be compressed by setting compressed: true in the config for this watcher

```
update (rcv_time, dp_id, msg)
```

```
class faucet.watcher.GaugePortStateLogger (conf, logname, prom_client)
```

Bases: *faucet.gauge\_pollers.GaugePortStateBaseLogger*

Abstraction for port state logger.

```
static no_response()
```

Called when a polling cycle passes without receiving a response.

```
static send_req()
```

Send a stats request to a datapath.

```
update (rcv_time, dp_id, msg)
```

```
class faucet.watcher.GaugePortStatsLogger (conf, logname, prom_client)
```

Bases: *faucet.gauge\_pollers.GaugePortStatsPoller*

Abstraction for port statistics logger.

```
update (rcv_time, dp_id, msg)
```

```
faucet.watcher.watcher_factory (conf)
```

Return a Gauge object based on type.

**Parameters** **conf** (*GaugeConf*) – object with the configuration for this valve.

## faucet.watcher\_conf module

Gauge watcher configuration.

```
class faucet.watcher_conf.WatcherConf (_id, dp_id, conf, prom_client)
```

Bases: *faucet.conf.Config*

Stores the state and configuration to monitor a single stat.

Watcher Config

Watchers are configured in the watchers config block in the config for gauge.

The following elements can be configured for each watcher, at the level of /watchers/<watcher name>/:

- type (string): The type of watcher (IE what stat this watcher monitors). The types are ‘port\_state’, ‘port\_stats’ or ‘flow\_table’.
- dps (list): A list of dps that should be monitored with this watcher.
- db (string): The db that will be used to store the data once it is retrieved.
- interval (int): if this watcher requires polling the switch, it will monitor at this interval.

The config for a db should be created in the gauge config file under the dbs config block.

The following elements can be configured for each db, at the level of /dbs/<db name>/:

- type (string): the type of db. The available types are ‘text’ and ‘influx’ for port\_state, ‘text’, ‘influx’ and ‘prometheus’ for port\_stats and ‘text’ and ‘gaugedb’ for flow\_table.

The following config elements then depend on the type. For text:

- file (string): the filename of the file to write output to.
- compress (bool): compress (with gzip) flow\_table output while writing it

### For influx:

- influx\_db (str): The name of the influxdb database. Defaults to ‘faucet’.
- influx\_host (str): The host where the influxdb is reachable. Defaults to ‘localhost’.
- influx\_port (int): The port that the influxdb host will listen on. Defaults to 8086.
- influx\_user (str): The username for accessing influxdb. Defaults to ‘’.
- influx\_pwd (str): The password for accessing influxdb. Defaults to ‘’.
- influx\_timeout (int): The timeout in seconds for connecting to influxdb. Defaults to 10.
- influx\_retries (int): The number of times to retry connecting to influxdb after failure. Defaults to 3.

### For Prometheus:

- prometheus\_port (int): The port used to export prometheus data. Defaults to 9303.
- prometheus\_addr (ip addr str): The address used to export prometheus data. Defaults to ‘127.0.0.1’.

#### `add_db(db_conf)`

Add database config to this watcher.

#### `add_dp(dp)`

Add a datapath to this watcher.

`all_dps = None`

`db = None`

`defaults = {'views': {}, 'prometheus_port': 9303, 'gdb_type': '', 'type': None, 'dp': None}`

`dp = None`

`prom_client = None`

## Module contents

# CHAPTER 3

---

## Quick References

---

### 3.1 Frequently Asked Questions

#### 3.1.1 How are packet-ins handled when a message is generated through table-miss flow entry?

Faucet adds explicit rules for unmatched packets.

#### 3.1.2 Are group actions supported in Faucet?

Yes, just not by default currently. Set the `group_table` option to `True` on a datapath to enable group output actions.

#### 3.1.3 Does Faucet send any multi-part requests? If so, please provide sample use cases

Gauge uses multi-part messages for the stats collection (flow table stats and port stats).

#### 3.1.4 Does Faucet install table-miss entry?

Yes.

#### 3.1.5 Does Faucet clear all switch table entries on connection?

Faucet gives all entries a specific cookie, and it clears all entries with that cookie. I.e., it clears entries added by itself but not anyone else.

**3.1.6 Does Faucet install fresh set of table entries on connection and re-connection?**

Yes.

**3.1.7 Does Faucet installed flows support priority? How is this defined - who get higher priority than the other and why?**

Yes, priority is necessary for a number of things. Example: there are higher priority rules for packets with a known source address, and lower ones to send those packets to the controller.

**3.1.8 Is there a gui for generating a YAML file?**

No.

**3.1.9 Should Faucet detect Management, OF controller ports and gateway ports on the switch or pure OF only ports where hosts are connected?**

Out of scope for Faucet as it is currently.

**3.1.10 If another controller is connected to the switch in addition to Faucet, what happens to Faucet?**

Faucet identifies its own flows using a cookie value, if the other controller doesn't use the same cookie value there shouldn't be a problem (provided the rules don't conflict in a problematic way)

**3.1.11 If another controller connected to switch changes role (master, slave, equal) on the switch, what happens to Faucet?**

Shouldn't be an issue, if another controller is the master then my understanding is Faucet wouldn't be able to install any flows however?

**3.1.12 Does Faucet send LLDP packets?**

No.

**3.1.13 Some switches always send VLAN info in packet\_in messages and some don't. How does Faucet handle this?**

Packets should have VLANs pushed before being sent to the controller.

**3.1.14 Is there a event handler registered to detect if flows on the switch change?**

No.

### **3.1.15 Does Faucet use auxiliary connections?**

No.

### **3.1.16 Does Faucet support L2.5 (MPLS, etc.)?**

No.

### **3.1.17 Stats - what does Faucet collect (flow count, etc.)?**

Gauge collects port stats and takes a full flow-table dump periodically.

### **3.1.18 How do I use Gauge?**

Give Gauge a list of Faucet yaml config files and it will poll them for stats (as specified in the config file).



# CHAPTER 4

---

## Indices and tables

---

- genindex
- modindex
- search



---

## Python Module Index

---

f

faucet, 88  
faucet.acl, 49  
faucet.check\_faucet\_config, 50  
faucet.conf, 50  
faucet.config\_parser, 51  
faucet.config\_parser\_util, 51  
faucet.dp, 52  
faucet.faucet, 54  
faucet.faucet\_bgp, 56  
faucet.faucet\_experimental\_api, 56  
faucet.faucet\_experimental\_event, 57  
faucet.faucet\_metrics, 57  
faucet.fctl, 57  
faucet.gauge, 58  
faucet.gauge\_influx, 59  
faucet.gauge\_nsodbc, 61  
faucet.gauge\_pollers, 62  
faucet.gauge\_prom, 63  
faucet.meter, 63  
faucet.nsodbc, 64  
faucet.port, 65  
faucet.prom\_client, 66  
faucet.router, 66  
faucet.tfm\_pipeline, 67  
faucet.valve, 67  
faucet.valve\_acl, 70  
faucet.valve\_flood, 71  
faucet.valve\_host, 71  
faucet.valve\_of, 72  
faucet.valve\_packet, 76  
faucet.valve\_route, 81  
faucet.valve\_table, 83  
faucet.valve\_util, 84  
faucet.vlan, 84  
faucet.watcher, 87  
faucet.watcher\_conf, 87



---

## Index

---

### A

ACL (class in faucet.acl), 49  
acl\_in (faucet.port.Port attribute), 65  
acl\_in (faucet.vlan.VLAN attribute), 84  
acls (faucet.dp.DP attribute), 52  
add() (faucet.valve\_table.ValveGroupEntry method), 83  
add\_acl() (faucet.dp.DP method), 52  
add\_cache\_host() (faucet.vlan.VLAN method), 84  
add\_db() (faucet.watcher\_conf.WatcherConf method), 88  
add\_dp() (faucet.watcher\_conf.WatcherConf method), 88  
add\_faucet\_vip() (faucet.valve\_route.ValveRouteManager method), 82  
add\_host\_fib\_route\_from\_pkt()  
    (faucet.valve\_route.ValveRouteManager method), 82  
add\_port() (faucet.dp.DP method), 52  
add\_port\_acl() (faucet.faucet\_experimental\_api.FaucetExperimentalAPI method), 56  
add\_route() (faucet.valve.Valve method), 67  
add\_route() (faucet.valve\_route.ValveRouteManager method), 82  
add\_router() (faucet.dp.DP method), 52  
add\_tagged() (faucet.vlan.VLAN method), 84  
add\_untagged() (faucet.vlan.VLAN method), 84  
add\_vlan() (faucet.dp.DP method), 52  
add\_vlan\_acl() (faucet.faucet\_experimental\_api.FaucetExperimentalAPI method), 56  
advertise() (faucet.faucet.Faucet method), 55  
advertise() (faucet.valve.Valve method), 67  
advertise() (faucet.valve\_route.ValveIPv6RouteManager method), 82  
advertise() (faucet.valve\_route.ValveRouteManager method), 82  
advertise\_interval (faucet.dp.DP attribute), 52  
all\_dps (faucet.watcher\_conf.WatcherConf attribute), 88  
all\_valve\_tables() (faucet.dp.DP method), 52  
apply\_actions() (in module faucet.valve\_of), 72  
apply\_meter() (in module faucet.valve\_of), 72  
arp\_neighbor\_timeout (faucet.dp.DP attribute), 52

arp\_reply() (in module faucet.valve\_packet), 77  
arp\_request() (in module faucet.valve\_packet), 77  
ArubaValve (class in faucet.valve), 67

### B

ban\_rules() (faucet.valve\_host.ValveHostManager method), 72  
barrier() (in module faucet.valve\_of), 72  
base\_prom\_labels (faucet.valve.Valve attribute), 67  
bgp\_as (faucet.vlan.VLAN attribute), 84  
bgp\_local\_address (faucet.vlan.VLAN attribute), 85  
bgp\_neighbor\_addresses (faucet.vlan.VLAN attribute), 85  
bgp\_neighbor\_as (faucet.vlan.VLAN attribute), 85  
bgp\_neighbour\_addresses (faucet.vlan.VLAN attribute), 85  
bgp\_neighbour\_as (faucet.vlan.VLAN attribute), 85  
bgp\_port (faucet.vlan.VLAN attribute), 85  
bgp\_routerid (faucet.vlan.VLAN attribute), 85  
bgp\_server\_addresses (faucet.vlan.VLAN attribute), 85  
btos() (in module faucet.valve\_util), 84  
bucket() (in module faucet.valve\_of), 73  
build\_acl\_entry() (in module faucet.valve\_acl), 70  
build\_acl\_ofmsgs() (in module faucet.valve\_acl), 70  
build\_flood\_rules() (faucet.valve\_flood.ValveFloodManager ExperimentalAPI method), 71  
build\_flood\_rules() (faucet.valve\_flood.ValveFloodStackManager method), 71  
build\_match\_dict() (in module faucet.valve\_of), 73  
build\_output\_actions() (in module faucet.valve\_acl), 70  
build\_pkt\_header() (in module faucet.valve\_packet), 77  
build\_port\_out\_inst() (faucet.valve\_host.ValveHostManager method), 72

### C

cached\_host() (faucet.vlan.VLAN method), 85  
cached\_host\_on\_port() (faucet.vlan.VLAN method), 85  
cached\_hosts\_on\_port() (faucet.vlan.VLAN method), 85  
check\_config() (faucet.conf.Conf method), 50

**check\_config()** (faucet.dp.DP method), 52  
**check\_config()** (faucet.port.Port method), 65  
**check\_config()** (faucet.router.Router method), 66  
**check\_config()** (faucet.vlan.VLAN method), 85  
**check\_config()** (in module faucet.check\_faucet\_config), 50  
**clear\_cache\_hosts\_on\_port()** (faucet.vlan.VLAN method), 85  
**Conf** (class in faucet.conf), 50  
**conf** (faucet.gauge\_influx.InfluxShipper attribute), 61  
**conf** (faucet.gauge\_nsodbc.GaugeNsODBC attribute), 61  
**conf\_hash()** (faucet.conf.Conf method), 50  
**config\_changed()** (in module faucet.config\_parser\_util), 51  
**config\_file\_hash()** (in module faucet.config\_parser\_util), 51  
**configured** (faucet.dp.DP attribute), 52  
**conn** (faucet.gauge\_nsodbc.GaugeNsODBC attribute), 61  
**conn\_string** (faucet.gauge\_nsodbc.GaugeNsODBC attribute), 61  
**connect()** (faucet.nsodbc.NsOdbc method), 64  
**connect\_or\_disconnect\_handler()** (faucet.faucet.Faucet method), 55  
**connected\_databases()** (faucet.nsodbc.ConnectionCouch method), 64  
**ConnectionCouch** (class in faucet.nsodbc), 64  
**CONTROL\_ETH\_TYPES**  
    (faucet.valve\_route.ValveIPv4RouteManager attribute), 81  
**CONTROL\_ETH\_TYPES**  
    (faucet.valve\_route.ValveIPv6RouteManager attribute), 81  
**CONTROL\_ETH\_TYPES**  
    (faucet.valve\_route.ValveRouteManager attribute), 82  
**control\_plane\_handler()** (faucet.valve.Valve method), 67  
**control\_plane\_handler()** (faucet.valve\_route.ValveIPv4RouteManager method), 81  
**control\_plane\_handler()** (faucet.valve\_route.ValveIPv6RouteManager method), 82  
**control\_plane\_handler()** (faucet.valve\_route.ValveRouteManager method), 82  
**controller\_pps\_meteradd()** (in module faucet.valve\_of), 73  
**controller\_pps\_meterdel()** (in module faucet.valve\_of), 73  
**cookie** (faucet.dp.DP attribute), 52  
**create()** (faucet.nsodbc.ConnectionCouch method), 64  
**create\_ryu\_structure()** (faucet.tfm\_pipeline.OpenflowToRyuTranslator method), 67  
**create\_view()** (faucet.nsodbc.DatabaseCouch method), 64

## D

**DatabaseCouch** (class in faucet.nsodbc), 64  
**datapath\_connect()** (faucet.valve.Valve method), 68  
**datapath\_disconnect()** (faucet.valve.Valve method), 68  
**db** (faucet.watcher\_conf.WatcherConf attribute), 88  
**db\_update\_counter** (faucet.gauge\_nsodbc.GaugeNsODBC attribute), 61  
**debug()** (faucet.valve.ValveLogger method), 70  
**dec\_ip\_ttl()** (in module faucet.valve\_of), 73  
**DEC\_TTL** (faucet.valve.ArubaValve attribute), 67  
**DEC\_TTL** (faucet.valve.Valve attribute), 67  
**defaults** (faucet.acl.ACL attribute), 50  
**defaults** (faucet.conf.Conf attribute), 50  
**defaults** (faucet.dp.DP attribute), 52  
**defaults** (faucet.meter.Meter attribute), 63  
**defaults** (faucet.port.Port attribute), 65  
**defaults** (faucet.router.Router attribute), 66  
**defaults** (faucet.vlan.VLAN attribute), 85  
**defaults** (faucet.watcher\_conf.WatcherConf attribute), 88  
**defaults\_type** (faucet.meter.Meter attribute), 64  
**defaults\_type** (faucet.router.Router attribute), 66  
**defaults\_types** (faucet.acl.ACL attribute), 50  
**defaults\_types** (faucet.conf.Conf attribute), 50  
**defaults\_types** (faucet.dp.DP attribute), 52  
**defaults\_types** (faucet.port.Port attribute), 65  
**defaults\_types** (faucet.vlan.VLAN attribute), 85  
**del\_route()** (faucet.valve.Valve method), 68  
**del\_route()** (faucet.valve\_route.ValveRouteManager method), 82  
**delete()** (faucet.nsodbc.ConnectionCouch method), 64  
**delete()** (faucet.valve\_table.ValveGroupEntry method), 83  
**delete\_all()** (faucet.valve\_table.ValveGroupTable method), 83  
**delete\_doc()** (faucet.nsodbc.DatabaseCouch method), 64  
**delete\_host\_from\_vlan()** (faucet.valve\_host.ValveHostManager method), 72  
**delete\_port\_acl()** (faucet.faucet\_experimental\_api.FaucetExperimentalAPI method), 57  
**delete\_vlan\_acl()** (faucet.faucet\_experimental\_api.FaucetExperimentalAPI method), 57  
**desc\_stats\_reply\_handler()** (faucet.faucet.Faucet method), 55  
**desc\_stats\_request()** (in module faucet.valve\_of), 73  
**devid\_present()** (in module faucet.valve\_of), 73  
**DP** (class in faucet.dp), 52  
**dp** (faucet.watcher\_conf.WatcherConf attribute), 88  
**dp\_config\_path()** (in module faucet.config\_parser\_util), 51  
    (dp\_id (faucet.dp.DP attribute), 52  
    (dp\_id (faucet.port.Port attribute), 65  
    (dp\_id (faucet.vlan.VLAN attribute), 85  
    (dp\_include() (in module faucet.config\_parser\_util), 51  
    (dp\_parser() (in module faucet.config\_parser), 51

dpid\_log() (in module faucet.valve\_util), 84  
 drop\_bpdu (faucet.dp.DP attribute), 52  
 drop\_broadcast\_source\_address (faucet.dp.DP attribute), 52  
 drop\_lldp (faucet.dp.DP attribute), 52  
 drop\_spoofed\_faucet\_mac (faucet.dp.DP attribute), 52  
 dyn\_faucet\_vips\_by\_ipv (faucet.vlan.VLAN attribute), 85  
 dyn\_finalized (faucet.conf.Conf attribute), 50  
 dyn\_hash (faucet.conf.Conf attribute), 50  
 dyn\_host\_cache (faucet.vlan.VLAN attribute), 85  
 dyn\_lacp\_up (faucet.port.Port attribute), 65  
 dyn\_lacp\_updated\_time (faucet.port.Port attribute), 65  
 dyn\_last\_ban\_time (faucet.port.Port attribute), 65  
 dyn\_last\_lacp\_pkt (faucet.port.Port attribute), 65  
 dyn\_learn\_ban\_count (faucet.port.Port attribute), 65  
 dyn\_learn\_ban\_count (faucet.vlan.VLAN attribute), 85  
 dyn\_neigh\_cache\_by\_ipv (faucet.vlan.VLAN attribute), 85  
 dyn\_phys\_up (faucet.port.Port attribute), 65  
 dyn\_routes\_by\_ipv (faucet.vlan.VLAN attribute), 85

## E

echo\_reply() (in module faucet.valve\_packet), 77  
 edge\_learn\_port() (faucet.valve\_flood.ValveFloodManager static method), 71  
 edge\_learn\_port() (faucet.valve\_flood.ValveFloodStackManager method), 71  
 enabled (faucet.port.Port attribute), 65  
 entries (faucet.valve\_table.ValveGroupTable attribute), 83  
 entry (faucet.meter.Meter attribute), 64  
 entry\_msg (faucet.meter.Meter attribute), 64  
 error() (faucet.valve.ValveLogger method), 70  
 error\_handler() (faucet.faucet.Faucet method), 55  
 ETH\_TYPE (faucet.valve\_route.ValveIPv4RouteManager attribute), 81  
 ETH\_TYPE (faucet.valve\_route.ValveIPv6RouteManager attribute), 81  
 ETH\_TYPE (faucet.valve\_route.ValveRouteManager attribute), 82  
 ETH\_TYPES\_PARSERS (faucet.valve\_packet.PacketMeta attribute), 76  
 EventFaucetAdvertise (class in faucet.faucet), 54  
 EventFaucetExperimentalAPIRegistered (class in faucet.faucet), 54  
 EventFaucetMetricUpdate (class in faucet.faucet), 54  
 EventFaucetReconfigure (class in faucet.faucet), 54  
 EventFaucetResolveGateways (class in faucet.faucet), 55  
 EventFaucetStateExpire (class in faucet.faucet), 55  
 EventGaugeReconfigure (class in faucet.gauge), 58  
 exact\_match (faucet.acl.ACL attribute), 50  
 exc\_logname (faucet.faucet.Faucet attribute), 55

exc\_logname (faucet.gauge.Gauge attribute), 58  
 expire\_cache\_hosts() (faucet.vlan.VLAN method), 85  
 expire\_hosts\_from\_vlan()  
 (faucet.valve\_host.ValveHostFlowRemovedManager method), 72  
 expire\_hosts\_from\_vlan()  
 (faucet.valve\_host.ValveHostManager method), 72

## F

Faucet (class in faucet.faucet), 55  
 faucet (module), 88  
 faucet.acl (module), 49  
 faucet.check\_faucet\_config (module), 50  
 faucet.conf (module), 50  
 faucet.config\_parser (module), 51  
 faucet.config\_parser\_util (module), 51  
 faucet.dp (module), 52  
 faucet.faucet (module), 54  
 faucet.faucet\_bgp (module), 56  
 faucet.faucet\_experimental\_api (module), 56  
 faucet.faucet\_experimental\_event (module), 57  
 faucet.faucet\_metrics (module), 57  
 faucet.fctl (module), 57  
 faucet.gauge (module), 58  
 faucet.gauge\_influx (module), 59  
 faucet.gauge\_nsodbc (module), 61  
 faucet.gauge\_pollers (module), 62  
 faucet.gauge\_prom (module), 63  
 faucet.meter (module), 63  
 faucet.nsodbc (module), 64  
 faucet.port (module), 65  
 faucet.prom\_client (module), 66  
 faucet.router (module), 66  
 faucet.tfm\_pipeline (module), 67  
 faucet.valve (module), 67  
 faucet.valve\_acl (module), 70  
 faucet.valve\_flood (module), 71  
 faucet.valve\_host (module), 71  
 faucet.valve\_of (module), 72  
 faucet.valve\_packet (module), 76  
 faucet.valve\_route (module), 81  
 faucet.valve\_table (module), 83  
 faucet.valve\_util (module), 84  
 faucet.vlan (module), 84  
 faucet.watcher (module), 87  
 faucet.watcher\_conf (module), 87  
 faucet\_async() (in module faucet.valve\_of), 73  
 faucet\_config() (in module faucet.valve\_of), 73  
 faucet\_mac (faucet.vlan.VLAN attribute), 85  
 faucet\_vips (faucet.vlan.VLAN attribute), 85  
 faucet\_vips\_by\_ipv() (faucet.vlan.VLAN method), 85  
 FaucetBgp (class in faucet.faucet\_bgp), 56

FaucetExperimentalAPI	(class faucet.faucet_experimental_api),	56	in	GaugePortStatsLogger (class in faucet.watcher),	87
FaucetExperimentalEventNotifier	(class faucet.faucet_experimental_event),	57	in	GaugePortStatsPoller (class in faucet.gauge_pollers),	63
FaucetMetrics	(class in faucet.faucet_metrics),	57	in	GaugePortStatsPrometheusPoller (class in faucet.gauge_prom),	63
features_handler()	(faucet.faucet.Faucet method),	55		GaugePrometheusClient (class in faucet.gauge_prom),	63
finalize()	(faucet.conf Conf method),	50		GaugeThreadPoller (class in faucet.gauge_pollers),	63
finalize()	(faucet.port.Port method),	65		get_attributes() (faucet.nsodbc.NsOdbc method),	64
finalize_config()	(faucet.dp.DP method),	52		get_bool_setting() (in module faucet.valve_util),	84
FLOOD_DSTS	(faucet.valve_flood.ValveFloodManager attribute),	71		get_config() (faucet.faucet.Faucet method),	55
flood_pkt()	(faucet.vlan.VLAN method),	85		get_config() (faucet.faucet_experimental_api.FaucetExperimentalAPI method),	57
flood_ports()	(faucet.vlan.VLAN method),	85		get_config_changes() (faucet.dp.DP method),	52
flood_tagged_port_outputs()	(in module faucet.valve_of),			get_config_dict() (faucet.dp.DP method),	53
73				get_config_dict() (faucet.valve.Valve method),	68
flood_untagged_port_outputs()	(in module faucet.valve_of),	73		get_config_for_api() (in module faucet.config_parser),	51
flow_database	(faucet.gauge_nsodbc.GaugeNsODBC at- tribute),	61		get_docs() (faucet.nsodbc.DatabaseCouch method),	64
flow_stats_reply_handler()	(faucet.gauge.Gauge method),			get_entry() (faucet.valve_table.ValveGroupTable method),	83
58				get_logger() (in module faucet.config_parser_util),	51
flow_timeout()	(faucet.valve.Valve method),	68		get_logger() (in module faucet.valve_util),	84
flow_timeout()	(faucet.valve_host.ValveHostFlowRemovedM- ethod),	72		get_native_vlan() (faucet.dp.DP method),	53
flow_timeout()	(faucet.valve_host.ValveHostManager method),	72		get_ports() (faucet.vlan.VLAN method),	86
flowcontroller()	(faucet.valve_table.ValveTable method),			Managing (in module faucet.valve_util),	84
83				get_sys_prefix() (in module faucet.valve_util),	84
flowdel()	(faucet.valve_table.ValveTable method),	83		get_tables() (faucet.dp.DP method),	53
flowdrop()	(faucet.valve_table.ValveTable method),	84		get_tables() (faucet.faucet.Faucet method),	55
flowmod()	(faucet.valve_table.ValveTable method),	84		get_tables() (faucet.faucet_experimental_api.FaucetExperimentalAPI method),	57
flowmod()	(in module faucet.valve_of),	73		goto_table() (in module faucet.valve_of),	73
flowremoved_handler()	(faucet.faucet.Faucet method),	55		group_act() (in module faucet.valve_of),	73
from_connected_to_vip()	(faucet.vlan.VLAN method),			group_flood_buckets() (in module faucet.valve_of),	74
85				group_id_from_str() (faucet.valve_table.ValveGroupTable static method),	83
<b>G</b>					
Gauge	(class in faucet.gauge),	58		group_table (faucet.dp.DP attribute),	53
gauge_async()	(in module faucet.valve_of),	73		group_table_routing (faucet.dp.DP attribute),	53
GaugeFlowTableDBLogger	(class faucet.gauge_nsodbc),	61	in	groupadd() (in module faucet.valve_of),	74
GaugeFlowTableInfluxDBLogger	(class faucet.gauge_influx),	59	in	groupadd_ff() (in module faucet.valve_of),	74
GaugeFlowTableLogger	(class in faucet.watcher),	87		groupdel() (in module faucet.valve_of),	74
GaugeFlowTablePoller	(class in faucet.gauge_pollers),	62		groupmod() (in module faucet.valve_of),	74
GaugeNsODBC	(class in faucet.gauge_nsodbc),	61		groupmod_ff() (in module faucet.valve_of),	74
GaugePoller	(class in faucet.gauge_pollers),	62		groups (faucet.dp.DP attribute),	53
GaugePortStateBaseLogger	(class faucet.gauge_pollers),	62	in		
GaugePortStateInfluxDBLogger	(class faucet.gauge_influx),	59	in	handler_reconnect() (faucet.gauge.Gauge method),	58
GaugePortStateLogger	(class in faucet.watcher),	87		high_priority (faucet.dp.DP attribute),	53
GaugePortStatsInfluxDBLogger	(class faucet.gauge_influx),	60	in	host_cache (faucet.vlan.VLAN attribute),	86
				HostCacheEntry (class in faucet.vlan),	84
				hosts() (faucet.port.Port method),	65
				hosts_count() (faucet.vlan.VLAN method),	86

**I**

ICMP\_TYPE (faucet.valve\_route.ValveIPv4RouteManager attribute), 81  
 ICMP\_TYPE (faucet.valve\_route.ValveIPv6RouteManager attribute), 82  
 ICMP\_TYPE (faucet.valve\_route.ValveRouteManager attribute), 82  
 icmpv6\_echo\_reply() (in module faucet.valve\_packet), 78  
 ignore\_learn\_ins (faucet.dp.DP attribute), 53  
 ignore\_port() (in module faucet.valve\_of), 74  
 ignore\_subconf() (faucet.conf.Conf method), 51  
 in\_port\_tables() (faucet.dp.DP method), 53  
 InfluxShipper (class in faucet.gauge\_influx), 61  
 info() (faucet.valve.ValveLogger method), 70  
 init\_flow\_db() (in module faucet.nsodbc), 65  
 init\_switch\_db() (in module faucet.nsodbc), 65  
 insert\_update\_doc() (faucet.nsodbc.DatabaseCouch method), 64  
 interface\_ranges (faucet.dp.DP attribute), 53  
 interfaces (faucet.dp.DP attribute), 53  
 InvalidConfigError, 51  
 ip\_header\_size() (in module faucet.valve\_packet), 78  
 ip\_in\_vip\_subnet() (faucet.vlan.VLAN method), 86  
 ip\_ver() (faucet.valve\_packet.PacketMeta method), 76  
 ips\_in\_vip\_subnet() (faucet.vlan.VLAN method), 86  
 IPV (faucet.valve\_route.ValveIPv4RouteManager attribute), 81  
 IPV (faucet.valve\_route.ValveIPv6RouteManager attribute), 82  
 IPV (faucet.valve\_route.ValveRouteManager attribute), 82  
 ipv4\_parseable() (in module faucet.valve\_packet), 78  
 ipv6\_link\_eth\_mcast() (in module faucet.valve\_packet), 78  
 ipv6\_solicited\_node\_from\_icast() (in module faucet.valve\_packet), 78  
 ipvs() (faucet.vlan.VLAN method), 86  
 is\_faucet\_vip() (faucet.vlan.VLAN method), 86  
 is\_flowdel() (in module faucet.valve\_of), 74  
 is\_flowmod() (in module faucet.valve\_of), 74  
 is\_groupadd() (in module faucet.valve\_of), 74  
 is\_groupdel() (in module faucet.valve\_of), 74  
 is\_groupmod() (in module faucet.valve\_of), 74  
 is\_registered() (faucet.faucet\_experimental\_api.FaucetExperimental API method), 57

**K**

kill\_on\_exception() (in module faucet.valve\_util), 84

**L**

L3 (faucet.valve.Valve attribute), 67  
 lacp\_down() (faucet.valve.Valve method), 68  
 lacp\_handler() (faucet.valve.Valve method), 68

lacp\_reqreply() (in module faucet.valve\_packet), 78

lacp\_up() (faucet.valve.Valve method), 68

lags() (faucet.vlan.VLAN method), 86

learn\_ban\_timeout (faucet.dp.DP attribute), 53

learn\_host\_on\_vlan\_port\_flows()

(faucet.valve\_host.ValveHostManager method), 72

learn\_host\_on\_vlan\_ports()

(faucet.valve\_host.ValveHostManager method), 72

learn\_host\_timeouts() (faucet.valve\_host.ValveHostFlowRemovedManager method), 72

learn\_host\_timeouts() (faucet.valve\_host.ValveHostManager method), 72

learn\_jitter (faucet.dp.DP attribute), 53

load\_tables() (faucet.tfm\_pipeline.LoadRyuTables method), 67

LoadRyuTables (class in faucet.tfm\_pipeline), 67

logger (faucet.gauge\_influx.InfluxShipper attribute), 61

logname (faucet.faucet.Faucet attribute), 55

logname (faucet.gauge.Gauge attribute), 58

loop\_protect (faucet.port.Port attribute), 65

low\_priority (faucet.dp.DP attribute), 53

**M**

mac\_addr\_is\_unicast() (in module faucet.valve\_packet), 79

mac\_byte\_mask() (in module faucet.valve\_packet), 79

main() (in module faucet.check\_faucet\_config), 50

main() (in module faucet.fctl), 57

make\_point() (faucet.gauge\_influx.InfluxShipper static method), 61

make\_port\_point() (faucet.gauge\_influx.InfluxShipper method), 61

match() (faucet.valve\_table.ValveTable method), 84

match() (in module faucet.valve\_of), 75

match\_from\_dict() (in module faucet.valve\_of), 75

match\_tables() (faucet.dp.DP method), 53

max\_host\_fib\_retry\_count (faucet.dp.DP attribute), 53

max\_hosts (faucet.port.Port attribute), 65

max\_hosts (faucet.vlan.VLAN attribute), 86

max\_hosts\_per\_resolve\_cycle (faucet.dp.DP attribute), 53

MAX\_LACP (faucet.valve\_route.ValveRouteManager attribute), 82

max\_resolve\_backoff\_time (faucet.dp.DP attribute), 53

merge\_dyn() (faucet.conf.Conf method), 51

Meter (class in faucet.meter), 63

meter\_id (faucet.meter.Meter attribute), 64

meteradd() (in module faucet.valve\_of), 75

meterdel() (in module faucet.valve\_of), 75

meters (faucet.dp.DP attribute), 53

metric\_update() (faucet.faucet.Faucet method), 55

metrics (faucet.gauge\_prom.GaugePrometheusClient attribute), 63  
 mirror (faucet.port.Port attribute), 65  
 mirror\_destination (faucet.port.Port attribute), 65  
 mirror\_destination\_ports() (faucet.vlan.VLAN method), 86  
 mirror\_destinations (faucet.acl.ACL attribute), 50  
 mirrored\_ports() (faucet.vlan.VLAN method), 86  
 modify() (faucet.valve\_table.ValveGroupEntry method), 83

## N

name (faucet.dp.DP attribute), 53  
 name (faucet.meter.Meter attribute), 64  
 name (faucet.port.Port attribute), 66  
 name (faucet.vlan.VLAN attribute), 86  
 native\_vlan (faucet.port.Port attribute), 66  
 nd\_advert() (in module faucet.valve\_packet), 79  
 nd\_request() (in module faucet.valve\_packet), 80  
 neigh\_cache\_by\_ipv() (faucet.vlan.VLAN method), 86  
 NextHop (class in faucet.valve\_route), 81  
 no\_duplicates\_constructor() (in module faucet.config\_parser\_util), 52  
 no\_response() (faucet.gauge\_pollers.GaugeFlowTablePoller method), 62  
 no\_response() (faucet.gauge\_pollers.GaugePoller static method), 62  
 no\_response() (faucet.gauge\_pollers.GaugePortStateBaseLogger static method), 62  
 no\_response() (faucet.gauge\_pollers.GaugePortStatsPoller method), 63  
 no\_response() (faucet.gauge\_pollers.GaugeThreadPoller static method), 63  
 no\_response() (faucet.watcher.GaugePortStateLogger static method), 87  
 notify() (faucet.faucet\_experimental\_event.FaucetExperimentalEvent method), 57  
 NsOdbc (class in faucet.nsodbc), 64  
 nsodbc\_factory() (in module faucet.nsodbc), 65  
 number (faucet.port.Port attribute), 66

## O

ofchannel\_log() (faucet.valve.Valve method), 68  
 OFP\_VERSIONS (faucet.faucet.Faucet attribute), 55  
 OFP\_VERSIONS (faucet.gauge.Gauge attribute), 58  
 OpenflowToRyuTranslator (class in faucet.tfm\_pipeline), 67  
 output\_controller() (in module faucet.valve\_of), 75  
 output\_in\_port() (in module faucet.valve\_of), 75  
 output\_port() (in module faucet.valve\_of), 75

## P

packet\_complete() (faucet.valve\_packet.PacketMeta method), 76

packet\_in\_handler() (faucet.faucet.Faucet method), 56  
 packetin\_pps (faucet.dp.DP attribute), 53  
 PacketMeta (class in faucet.valve\_packet), 76  
 packetout() (in module faucet.valve\_of), 75  
 parse\_eth\_pkt() (in module faucet.valve\_packet), 80  
 parse\_lacp\_pkt() (in module faucet.valve\_packet), 80  
 parse\_packet\_in\_pkt() (in module faucet.valve\_packet), 80  
 parse\_rcv\_packet() (faucet.valve.Valve method), 68  
 parse\_vlan\_pkt() (in module faucet.valve\_packet), 80  
 peer\_stack\_up\_ports() (faucet.dp.DP method), 53  
 permanent\_learn (faucet.port.Port attribute), 66  
 PIPELINE\_CONF (faucet.valve.ArubaValve attribute), 67  
 PIPELINE\_CONF (faucet.valve.TfmValve attribute), 67  
 pipeline\_config\_dir (faucet.dp.DP attribute), 53  
 pop\_vlan() (in module faucet.valve\_of), 75  
 Port (class in faucet.port), 65  
 port\_add() (faucet.valve.Valve method), 68  
 port\_delete() (faucet.valve.Valve method), 69  
 port\_is\_tagged() (faucet.vlan.VLAN method), 86  
 port\_is\_untagged() (faucet.vlan.VLAN method), 86  
 port\_stats\_reply\_handler() (faucet.gauge.Gauge method), 58  
 port\_status\_handler() (faucet.faucet.Faucet method), 56  
 port\_status\_handler() (faucet.gauge.Gauge method), 58  
 port\_status\_handler() (faucet.valve.Valve method), 69  
 ports (faucet.dp.DP attribute), 53  
 ports\_add() (faucet.valve.Valve method), 69  
 ports\_delete() (faucet.valve.Valve method), 69  
 priority\_offset (faucet.dp.DP attribute), 54  
 proactive\_arp\_limit (faucet.vlan.VLAN attribute), 86  
 proactive\_learn (faucet.dp.DP attribute), 54  
 proactive\_nd\_limit (faucet.vlan.VLAN attribute), 86  
 prom\_client (faucet.watcher\_conf.WatcherConf attribute), 88  
 PromClient (class in faucet.prom\_client), 66  
 push\_config() (faucet.faucet\_experimental\_api.FaucetExperimentalAPI method), 57  
 push\_vlan() (in module faucet.valve\_acl), 70  
 push\_vlan\_act() (in module faucet.valve\_of), 75

## R

rcv\_packet() (faucet.valve.Valve method), 69  
 read\_config() (in module faucet.config\_parser\_util), 52  
 recent\_ofmsgs (faucet.valve.Valve attribute), 69  
 reconnect\_handler() (faucet.faucet.Faucet method), 56  
 refresh\_flowdb() (faucet.gauge\_nsodbc.GaugeNsODBC method), 61  
 refresh\_switchdb() (faucet.gauge\_nsodbc.GaugeNsODBC method), 62  
 reload\_config() (faucet.faucet.Faucet method), 56  
 reload\_config() (faucet.faucet\_experimental\_api.FaucetExperimentalAPI method), 57

reload\_config() (faucet.gauge.Gauge method), 59  
 reload\_config() (faucet.valve.Valve method), 69  
 reparse() (faucet.valve\_packet.PacketMeta method), 76  
 reparse\_all() (faucet.valve\_packet.PacketMeta method), 77  
 reparse\_ip() (faucet.valve\_packet.PacketMeta method), 77  
 report\_dp\_status() (faucet.gauge\_pollers.GaugePoller method), 62  
 report\_label\_match\_metrics() (in module faucet.fctl), 58  
 REQUIRED\_LABELS (faucet.prom\_client.PromClient attribute), 66  
 reset() (faucet.faucet\_bgp.FaucetBgp method), 56  
 reset\_dpid() (faucet.faucet\_metrics.FaucetMetrics method), 57  
 reset\_host\_cache() (faucet.vlan.VLAN method), 86  
 resolve\_gateways() (faucet.faucet.Faucet method), 56  
 resolve\_gateways() (faucet.valve.Valve method), 69  
 resolve\_gateways() (faucet.valve\_route.ValveRouteManager method), 83  
 resolve\_gw\_on\_vlan() (faucet.valve\_route.ValveRouteManager method), 83  
 resolve\_stack\_topology() (faucet.dp.DP method), 54  
 rewrite\_vlan() (in module faucet.valve\_acl), 70  
 Router (class in faucet.router), 66  
 router\_advert() (in module faucet.valve\_packet), 80  
 routers (faucet.dp.DP attribute), 54  
 routes (faucet.vlan.VLAN attribute), 86  
 routes\_by\_ipv() (faucet.vlan.VLAN method), 86  
 rules (faucet.acl.ACL attribute), 50  
 running (faucet.dp.DP attribute), 54  
 running (faucet.prom\_client.PromClient attribute), 66  
 running() (faucet.gauge\_pollers.GaugePoller static method), 62  
 running() (faucet.gauge\_pollers.GaugeThreadPoller method), 63  
 running() (faucet.port.Port method), 66

**S**

scrape\_prometheus() (in module faucet.fctl), 58  
 send\_req() (faucet.gauge\_pollers.GaugeFlowTablePoller method), 62  
 send\_req() (faucet.gauge\_pollers.GaugePoller static method), 62  
 send\_req() (faucet.gauge\_pollers.GaugePortStateBaseLogger static method), 63  
 send\_req() (faucet.gauge\_pollers.GaugePortStatsPoller method), 63  
 send\_req() (faucet.gauge\_pollers.GaugeThreadPoller static method), 63  
 send\_req() (faucet.watcher.GaugePortStateLogger static method), 87  
 set\_defaults() (faucet.conf.Conf method), 51  
 set\_defaults() (faucet.dp.DP method), 54

set\_defaults() (faucet.port.Port method), 66  
 set\_defaults() (faucet.vlan.VLAN method), 86  
 set\_ether\_dst() (in module faucet.valve\_of), 76  
 set\_ether\_src() (in module faucet.valve\_of), 76  
 set\_vlan\_vid() (in module faucet.valve\_of), 76  
 setup() (faucet.gauge\_nsodbc.GaugeNsODBC method), 62

ship\_error\_prefix (faucet.gauge\_influx.InfluxShipper attribute), 61  
 ship\_points() (faucet.gauge\_influx.InfluxShipper method), 61  
 shortest\_path() (faucet.dp.DP method), 54  
 shortest\_path\_port() (faucet.dp.DP method), 54  
 shortest\_path\_to\_root() (faucet.dp.DP method), 54  
 signal\_handler() (faucet.gauge.Gauge method), 59  
 SKIP\_VALIDATION\_TABLES (faucet.valve.TfmValve attribute), 67  
 stack (faucet.dp.DP attribute), 54  
 stack\_ports (faucet.dp.DP attribute), 54  
 start() (faucet.faucet.Faucet method), 56  
 start() (faucet.faucet\_experimental\_event.FaucetExperimentalEventNotifier method), 57  
 start() (faucet.gauge.Gauge method), 59  
 start() (faucet.gauge\_pollers.GaugePoller static method), 62  
 start() (faucet.gauge\_pollers.GaugeThreadPoller method), 63  
 start() (faucet.prom\_client.PromClient method), 66  
 stat\_config\_files() (in module faucet.valve\_util), 84  
 state\_expire() (faucet.faucet.Faucet method), 56  
 state\_expire() (faucet.valve.Valve method), 70  
 stop() (faucet.gauge\_pollers.GaugePoller static method), 62  
 stop() (faucet.gauge\_pollers.GaugeThreadPoller method), 63  
 switch\_database (faucet.gauge\_nsodbc.GaugeNsODBC attribute), 62  
 switch\_features() (faucet.valve.TfmValve method), 67  
 switch\_features() (faucet.valve.Valve method), 70

**T**

table\_features() (in module faucet.valve\_of), 76  
 tables (faucet.dp.DP attribute), 54  
 tables\_by\_id (faucet.dp.DP attribute), 54  
 tagged (faucet.vlan.VLAN attribute), 86  
 tagged\_flood\_ports() (faucet.vlan.VLAN method), 86  
 tagged\_vlans (faucet.port.Port attribute), 66  
 TfmValve (class in faucet.valve), 67  
 timeout (faucet.dp.DP attribute), 54  
 to\_conf() (faucet.acl.ACL method), 50  
 to\_conf() (faucet.conf.Conf method), 51  
 to\_conf() (faucet.dp.DP method), 54  
 to\_conf() (faucet.port.Port method), 66

todict() (in module faucet.nsodbc), 65

### U

unicast\_flood (faucet.port.Port attribute), 66

unicast\_flood (faucet.vlan.VLAN attribute), 86

untagged (faucet.vlan.VLAN attribute), 86

untagged\_flood\_ports() (faucet.vlan.VLAN method), 87

update() (faucet.conf.Conf method), 51

update() (faucet.gauge\_influx.GaugeFlowTableInfluxDBLogger  
method), 59

update() (faucet.gauge\_influx.GaugePortStateInfluxDBLogger  
method), 60

update() (faucet.gauge\_influx.GaugePortStatsInfluxDBLogger  
method), 61

update() (faucet.gauge\_nsodbc.GaugeFlowTableDBLogger  
method), 61

update() (faucet.gauge\_pollers.GaugePoller method), 62

update() (faucet.gauge\_prom.GaugePortStatsPrometheusPoller  
method), 63

update() (faucet.watcher.GaugeFlowTableLogger  
method), 87

update() (faucet.watcher.GaugePortStateLogger method),  
87

update() (faucet.watcher.GaugePortStatsLogger method),  
87

update\_buckets() (faucet.valve\_table.ValveGroupEntry  
method), 83

update\_config\_metrics() (faucet.valve.Valve method), 70

update\_metrics() (faucet.faucet\_bgp.FaucetBgp method),  
56

update\_metrics() (faucet.valve.Valve method), 70

usage() (in module faucet.fctl), 58

use\_idle\_timeout (faucet.dp.DP attribute), 54

### V

Valve (class in faucet.valve), 67

valve\_factory() (in module faucet.valve), 70

valve\_flowreorder() (in module faucet.valve\_of), 76

valve\_match\_vid() (in module faucet.valve\_of), 76

ValveFloodManager (class in faucet.valve\_flood), 71

ValveFloodStackManager (class in faucet.valve\_flood),  
71

ValveGroupEntry (class in faucet.valve\_table), 83

ValveGroupTable (class in faucet.valve\_table), 83

ValveHostFlowRemovedManager (class in  
faucet.valve\_host), 71

ValveHostManager (class in faucet.valve\_host), 72

ValveIPv4RouteManager (class in faucet.valve\_route), 81

ValveIPv6RouteManager (class in faucet.valve\_route), 81

ValveLogger (class in faucet.valve), 70

ValveRouteManager (class in faucet.valve\_route), 82

ValveTable (class in faucet.valve\_table), 83

vid (faucet.vlan.VLAN attribute), 87

vid\_present() (in module faucet.valve\_of), 76

vid\_valid() (faucet.vlan.VLAN static method), 87

VLAN (class in faucet.vlan), 84

vlan\_match\_tables() (faucet.dp.DP method), 54

vlans (faucet.dp.DP attribute), 54

vlans (faucet.router.Router attribute), 66

vlans() (faucet.port.Port method), 66

### W

warning() (faucet.valve.ValveLogger method), 70

watcher\_factory() (in module faucet.watcher), 87

watcher\_parser() (in module faucet.config\_parser), 51

WatcherConf (class in faucet.watcher\_conf), 87

wildcard\_table (faucet.dp.DP attribute), 54